

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2017/SZ/ 1426

Dated: 27/9/17

FIRE SAFETY CERTIFICATE

Certified that the **Shepherd's Path International School** located at **G-72, Shaheen Bagh, Jamia Nagar, New Delhi-110025**, running at ground and first floor of the building comprised of **Basement** (others property), **Ground + three upper floors** (2nd & 3rd floor- others property) was inspected by the officer concerned of this department on 27/07/2017 in presence of Mr. Ahmad Rahmani (Admin. Mgr) of the school and found that the said building have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "**Educational Building**" Group-B, as above with effect from the date of issue of this certificate for a period of **Three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/9/17 at New Delhi by

28/9
(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Principal, Shepherd's Path International School,
G-72, Shaheen Bagh, Jamia Nagar, New Delhi-110025
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| | | | | |
|-------|---|---|---|----------------|
| 1 | Name & Address of the Building | SHEPHARD'S PATH INTERNATIONAL SCHOOL, G-72, SHAHEEN BAGH, JAMIA NAGAR,,NEW DELHI-110025 | | |
| 2 | Type of Occupancy | Educational Building "Group-B" (School) | | |
| 3 | Building Comprised of | Basement, Ground + 3 upper floors. | | |
| 4 | Type of Case | New | | |
| 5 | Details of Previous NOC | Nil | | |
| 6 | Fire Safety Directives Letter No | F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 ✓ | | |
| 7 | Date of Inspection | 27-07-2017 | | |
| 8 | Name of the Inspecting Officers | ADO R.N. Singh | | |
| 9 | Name & Designation of Officers from the building side | Mr. Ahmad Rahmani (Admin Mgr) | | |
| 10 | Year of construction | 2008 | School running at Ground & First floor only ✓ | |
| 11 | Applicant letter No. | SPIS/2017/ADMIN/FD-03 Dt. 21/07/2017 (C-10) | | |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | DOE circular requirements | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | 1. Road width | Accessible | 12 mtr | MR |
| | 2. Gate width | -NA- | Directly accessible from road | -NA- |
| | 3. Width of internal road | -NA- | -NA- | -NA- |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a. Number of Staircase | | | |
| | 1. Upper floors | One | Two | MR |
| | 2. Basement floor | -NA- | Others property | -NA- |
| | b. Width of Staircase | | | |
| | 1. Upper floors | 1.50 m/0.75 m | 1.06 mtr & 1.25 mtr | MR ✓ |
| | 2. Basement floor | -NA- | -NA- | -NA- |
| | c. Protection of exits | | | |
| | 1. Fire check door | -NA- | -NA- | -NA- |
| | 2. Pressurization | -NA- | -NA- | -NA- |
| | d. No. of continuous staircase to terrace | -NA- | -NA- | -NA- |
| | e. Width of corridor | -NA- | -NA- | -NA- |
| | f. Door size | 1m | 1m | MR |
| 3 | Compartmentation. | | | |
| | 1. Fire check door. | -NA- | -NA- | -NA- |
| | 2. Sealing of electrical shafts. | -NA- | -NA- | -NA- |
| | 3. Fire rating of shaft door. | -NA- | -NA- | -NA- |
| | 4. Water curtain | -NA- | -NA- | -NA- |
| | 5. Fire dampers. | -NA- | -NA- | -NA- |
| 4. | Smoke Management system. | | | |
| | 1. Basement | -NA- | -NA- | -NA- |
| | 2. Upper floors | -NA- | -NA- | -NA- |
| 5. | Fire Extinguishers. | | | |
| | 1. Total numbers | 6 No's | 8 No's | MR |
| | 2. Types | ABC /Co2 | ABC-6, Co2-2 | MR |
| | 3. ISI Marking | ISI Marked | Provided | MR |
| 6. | First Aid Hose Reels. | | Not required | |
| | 1. Total numbers on each floor. | -NA- | -NA- | -NA- |
| | 2. Length of hose-reel hose. | -NA- | -NA- | -NA- |
| | 3. Nozzle Diameter | -NA- | -NA- | -NA- |

| | | | | |
|------------|--|--------------|-----------------|------|
| 7 | Automatic Fire Detection and Alarming System. | | | |
| | 1. Type of detectors | -NA- | -NA- | -NA- |
| | 2. Location of Main Panel | -NA- | -NA- | -NA- |
| | 3. Location of Repeater Panel | -NA- | -NA- | -NA- |
| | 4. Alternate source of power | -NA- | -NA- | -NA- |
| | 5. Hooter's location | -NA- | -NA- | -NA- |
| 8. | MOEFA / SIREN | -NA- | -NA- | -NA- |
| 9. | Public Address System | -NA- | -NA- | -NA- |
| 10. | Automatic Sprinkler System | | | |
| | 1. Basement. | -NA- | Others property | -NA- |
| | 2. Upper floors | -NA- | -NA- | -NA- |
| | 3. Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants. | | | |
| | 1. Size of Riser / Down-comer | -NA- | -NA- | -NA- |
| | 2. Number of Hydrant per floor | -NA- | -NA- | -NA- |
| | 3. Hose box. | -NA- | -NA- | -NA- |
| 12. | Yard Hydrants. | | | |
| | 1. Total number of hydrants. | -NA- | -NA- | -NA- |
| | 2. Hose box. | -NA- | -NA- | -NA- |
| 13. | Pumping arrangements. | | | |
| | • Ground Level | Not required | | |
| | ➤ Discharge of main pump. | -NA- | -NA- | -NA- |
| | ➤ Head of main pump. | -NA- | -NA- | -NA- |
| | ➤ Number of main pumps. | -NA- | -NA- | -NA- |
| | ➤ Jockey Pump output. | -NA- | -NA- | -NA- |
| | ➤ Jockey Pump head. | -NA- | -NA- | -NA- |
| | ➤ Standby Pump output. | -NA- | -NA- | -NA- |
| | ➤ Standby Pump head. | -NA- | -NA- | -NA- |
| | ➤ Auto Starting / Manual Stopping. | -NA- | -NA- | -NA- |
| | • Terrace Level | Not required | | |
| | ➤ Discharge of pump. | -NA- | -NA- | -NA- |
| | ➤ Head of pump. | -NA- | -NA- | -NA- |
| | ➤ Power supply. | -NA- | -NA- | -NA- |
| | ➤ Auto starting of pump. | -NA- | -NA- | -NA- |
| 14. | Captive water storage for fire fighting. | | | |
| | • Underground tank capacity. | -NA- | -NA- | -NA- |
| | ➤ Draw-off connection. | -NA- | -NA- | -NA- |
| | ➤ Fire Service Inlet. | -NA- | -NA- | -NA- |
| | ➤ Access to tank. | -NA- | -NA- | -NA- |
| | • Overhead tank capacity. | -NA- | -NA- | -NA- |
| 15. | Exit Signage. | -NA- | -NA- | -NA- |
| 16. | Provision of Lifts. | | | |
| | Not required | | | |
| | 1. Pressurization of lift shaft. | -NA- | -NA- | -NA- |
| | 2. Pressurization of lift lobby. | -NA- | -NA- | -NA- |
| | 3. Communication in lift car. | -NA- | -NA- | -NA- |
| | 4. Fireman's switch. | -NA- | -NA- | -NA- |
| | 5. Lift signage. | -NA- | -NA- | -NA- |
| 17 | Standby Power Supply | -NA- | -NA- | -NA- |
| 18. | Refuge Area | | | |
| | Not required | | | |
| | 1. Total area | -NA- | -NA- | -NA- |
| | 2. Location | -NA- | -NA- | -NA- |

| 19. | Fire Control Room. | Not required | | |
|-----|--|--------------|---|------|
| | 1. Detector System Panel. | -NA- | -NA- | -NA- |
| | 2. Flow Switch Panel. | -NA- | -NA- | -NA- |
| | 3. PA system Panel. | -NA- | -NA- | -NA- |
| | 4. Battery backup | -NA- | -NA- | -NA- |
| | 5. Building floor plan | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | -NA- | Co2 type fire extinguisher provided near electrical panel | -NA- |

The Fire protection systems provided in the building were checked randomly and found functional at the time of inspection.

Keeping in view the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures required under the Directorate of Education circular, it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.

Signature
15/9/17

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO

Shepherd's Path International School, G-72, Shaheen Bagh, Jamia Nagar, New Delhi

D.O (SD)

Signature
19/9/17

Signature
19/9/17



Signature
19/9

FTM.

Signature

Signature
21/9

F.T letter is put up for sign. ple. *Signature*
23/9

1249/cfo sc
26/9.

Signature

Signature
25/9.