

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2017/SZ/ 1466

Dated: 6/10/17

**FIRE SAFETY CERTIFICATE**

Certified that the Restaurant in the name & style of **WD House** (A Unit of Spinning Plates Hospitality Pvt. Ltd.) running at ground, first & second floor of M-80, M-Block Market, Greater Kailash-II, New Delhi-110048, comprised of **basement** (not part of restt.), **ground and two upper floors** was inspected by the officer concerned of this department on 20/09/2017 in the presence of Mr. Amber (Director) of the eating house and observed that the said building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class-D "**Assembly Building**" as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 6/10/17 at New Delhi by

*W.K.*  
(Vipin Kental)  
Chief Fire Officer  
Ph. 011-23412225

Copy to: -

1. The DHO (South Zone), South MCD, Health Deptt, , New Delhi-24
2. M/s WD House Restt., M-80, M-Block Market, Greater Kailash-II, New Delhi-110048

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



## INSPECTION REPORT

1	Name & Address of the Building	M/s W D HOUSE RESTAURANT located at M-80, GF, FF & SF, M-Block Mkt, Greater Kailash-II, ND-48		
2	Type of Occupancy	Assembly buildings 'Group-D'		
3	Building comprised of	Basement, Ground plus two upper floors.		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Cir. No. 4/22/2004/HP-III/356 -369 Dt. 22-03-2005		
7	Date of Inspection	20-09-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Amber (Director)		
10	Year of construction	1996   Restt at ground, 1 <sup>st</sup> & 2 <sup>nd</sup> floor of the bldg		
11	Applicant letter No.	DHO/SZ/2017/D-945 dated 23.08.2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per Circular (22/03/2005) & Directives at N/3	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	9 mtr N/A N/A	9 mtr N/A N/A	MR N/A N/A
2	<b>Number, width, type &amp; arrangement of exits</b>			
	<b>a. Number of Staircase</b>			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>	Two N/A	Two N/A	MR N/A
	<b>b. Width of Staircase</b>			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>	1.25 mtr N/A	1.17 & 1.50 mtr N/A	MR N/A
	<b>c. Protection of exits</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	<b>d. No. of continuous staircase to terrace</b>	One	Two	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1 mtr	2.0 & 1.20 mtr	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	N/A N/A	N/A N/A	N/A N/A
5.	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	10 No's ABC / Co2 ISI marked	12 No's ABC-08, Co2-04 Provided	MR MR MR
6.	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	One 30 m 5 mm	One 30 m 5 mm	MR MR MR



7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	<b>MOEFA/MCP's</b>	Required	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	N/A	100 mm	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	225 & 180 LPM	450 & 180 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 ltrs	10,000 ltrs	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A



19.	<b>Fire Control Room.</b>				
		• Detector System Panel.	N/A	N/A	N/A
		• Flow Switch Panel.	N/A	N/A	N/A
		• PA system Panel.	N/A	N/A	N/A
		• Battery backup	N/A	N/A	N/A
		• Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any :</b>	N/A	N/A	N/A	
<p>The Fire protection systems provided in the building were checked / operated and found functional at the time of inspection.</p> <p>Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.</p> <p>Accordingly, DFA is put up for approval and signature please.</p>					
<p><i>R.N. Singh</i> 20/9/17</p> <p>Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO</p>					

Div. Officer (SD)

The requirement generated by you are not as per direction No 5 of FPO. It seems they are generated from old circular issued for restaurants. Kindly clarify.

*ADP*  
20/9/17

*Anilash*  
20/9/17