

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/2017/SZ/ 1469

Dated: 6/10/17

FIRE SAFETY CERTIFICATE

Certified that M/s Springdales School, at Benito Juarez Marg, Dhaula Kuan, New Delhi-110021, comprised of Basement (storage only), ground plus three upper floors, owned/occupied by Springdales School was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2014/1300, dated 17-10-2014. The premises was re-inspected by the officer concerned of this department on 20-09-2017 in the presence of Sh. Pawan Kumar (Administrator) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.262-362, dated 17.01.2005 by Director of Education and that the premises is fit for Occupancy Class-B "Educational" with effect from ...6/10/2017 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...6/10/2017 at New Delhi by.


6/10
(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

Copy to:-1. Principal, Springdales School, Benito Juarez Marg,
Dhaulta Kuan, New Delhi-110021.

2. Director of Education, Old Secretariat, Civil Lines, Delhi.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Springdales School, at Benito Juarez Marg, Dhaula Kuan, New Delhi-110021.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/2014/SZ/1300, dated 17.10.2014.		
5	Fire safety directives letter No	Circular No. 262-362 From Director of Education		
6	Date of inspection	20.09.2017		
7	Name of the inspecting Officers	A.D.O. Vedpal.		
8	Name and designation of officers from the building side	Sh. Pawan Kumar (Administrator)		
9	Building Comprised of	B+G+3(Two Blocks)		
10	Year of construction	1986		
11	Applicant's letter No.	1119/2014, dated 21.08.2014.		

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per Circular No. 262-362	Provided at site	Remarks MR / NMR
--------	---	--	------------------	------------------

1	Access to building			
	1) Road width	Required	12m	MR
	2) Gate width	Required	5m	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Required	1no in senior block, 3no. In second block.	MR(Old case)
	2. basements	Required	1no.(each basement)	MR(Old case)
	b. Width of staircase			
	1. Upper floors	1.5m/75cm	1.35cm(senior block), 1.75,1.30&1.5m in another block	MR(Old case)
	2. basements	1.5/75cm	80cm in senior block & 1.40 in second block.	MR(Old case)
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	1no in senior block, 2nos. In second block.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1m	1m	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	30 a/c per hour	Exhaust Fans	MR
	upper floors	12 a/c per hour	Provided	
			N/A	N/A

5	Fire Extinguishers			
	total numbers	40nos.	40nos.	MR
		ABC,WCO2& CO2	ABC & Water CO2	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	Senior Block=1no, Second Block=02nos.	Senior Block=1no, Second Block=02nos.	MR
	Length of Hose reel hose	30 m	30m	MR
	Nozzle Diameter	5 mm	5mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	100mm	N/A
	Number of Hydrants per floor	N/A	1no.+02nos.	N/A
	hose Box	N/A	1no.+02nos.	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level	N/A	N/A	N/A
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450LPM(Each), 02nos.	450LPM(Each), 03nos.	MR
	b. head of the pump	40 mtr(Each)	40m(Each)	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000Ltr. each (2nos.)	10000Liters each(3nos.)	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
		N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: N/A			

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the Circular No.262-362, dated 17.01.2005 by Director of Education, the FSC issued vide letter No.F.6/DFS/MS/2014/SZ/1300, dated 17.10.2014 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

[Handwritten Signature] 21/9/17

Signature of the inspecting officer

Name: Vedpal

Designation : ADO

~~D.O. (SD)~~

~~*[Handwritten Signature]*~~
21/9/17

~~*[Handwritten Signature]*~~

1261/CF 82
21/9/17

[Handwritten Signature]
20/9



CFOS 21 M-sell FT letter is put up for sign please
[Handwritten Signature] 20/9