

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/Club/2017/SZ/ 1481

Dated: 10/10/17

FIRE SAFETY CERTIFICATE

Certified that the **Safdarjung Club** located at **Safdarjung Enclave, New Delhi-110029**, comprised of **basement, ground plus two upper floors** was granted FSC by this department vide letter No. F.6/DFS/MS/Club/2014/SZ/33 dated 10/01/2014. The premises was re-inspected by the officer concerned of this department on 20.09.2017 in the presence of Mr. Binay Kumar Jha (Dy. Admin Officer) and found that the said club building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group-D "**Assembly Building**" as above with effect from the date of issuance of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/10/17 at New Delhi by

u
10/10
Vipin Kental
Chief Fire Officer
Ph. 011-23412225

Copy to: -

1. The Dy. Admn Officer, M/s Safdarjung Club, Safdarjung Enclave, New Delhi-110029
2. The DEO, Office of the Commissioner of Excise, Govt. of NCTD, L & N Block, I.P. Estate, Vikas Bhawan, New Delhi- 110002

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. This Certificate cannot be treated as regularization of unauthorized construction, if any.
6. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT				
1	Name & Address of the Building	Safdarjung Club, Safdarjung Enclave, New Delhi-110029		
2	Type of Occupancy	Assembly Building "CLUB"		
3	Building Comprised of	Basement, Ground, plus two upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Club/2014/SZ/33 dated 10-01-2014		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/90/258 dated 27-02-1990		
7	Date of Inspection	04.03.2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Binay Kumar Jha, (Dy. Admin Officer)		
10	Year of construction	1973		
11	Applicant letter No.	SJC/Fire NOC/2017 Dated 30/01/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Dt. 19/01/2007 & Directives requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	Required	9 mtr	MR
	2. Gate width	Required	4.20, 367. 3.78 & 1.94m	MR
	3. Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	1. Upper floors	Required	2 No's	MR
	2. Basement floor	Required	2 No's	MR
	b. Width of Staircase			
	1. Upper floors	Required	1.36m & 0.90m	MR (old case)
	2. Basement floor	Required	1.36m & 0.90m	MR (old case)
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	2 No's	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3	Compartmentation.			
	1. Fire check door.	Required	Provided	MR
	2. Sealing of electrical shafts.	N/A	N/A	N/A
	3. Fire rating of shaft door.	N/A	N/A	N/A
	4. Water curtain	N/A	N/A	N/A
	5. Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	1. Basement	Required	Exhaust fan provided	MR
	2. Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers.			
	1. Total numbers	ISI marked	25 No's	MR
	2. Types		ABC- 20, Co2- 05	MR
	3. ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.	Hose Reel	One	MR
	2. Length of hose-reel hose.		30 mtr	MR
	3. Nozzle Diameter		05 mm	MR

Renewal

Safdarjung Club, Safdarjung Enclave, New Delhi-29

7	Automatic fire detection & alarming system.			
	1. Type of detectors	N/A	N/A	N/A
	2. Location of Main Panel	N/A	N/A	N/A
	3. Location of Repeater Panel	N/A	N/A	N/A
	4. Alternate source of power	N/A	N/A	N/A
	5. Hooter's location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	1. Basement	Required	Provided	MR
	2. Upper floors	Required	Provided	MR
	3. Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	1. Size of Riser/Down-comer	N/A	N/A	N/A
	2. Number of Hydrant per floor	N/A	N/A	N/A
	3. Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	1. Total number of hydrants.	N/A	N/A	N/A
	2. Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	b) Terrace Level			
	➤ Discharge of pump.	Required	900 LPM	MR
	➤ Head of pump.	Required	40 mtr	MR
	➤ Power supply.	Required	DG Set provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	1. Underground tank capacity.	N/A	N/A	N/A
	2. Draw-off connection.	N/A	N/A	N/A
	3. Fire Service Inlet.	N/A	N/A	N/A
	4. Access to tank.	N/A	N/A	N/A
	5. Overhead tank capacity.	5,000 Ltr.	10,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	1. Pressurization of lift shaft.	N/A	N/A	N/A
	2. Pressurization of lift lobby.	N/A	N/A	N/A
	3. Communication in lift car.	N/A	N/A	N/A
	4. Fireman's switch.	N/A	N/A	N/A
	5. Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA

19.	Fire Control Room.			
	1. Detector System Panel.	NA	NA	NA
	2. Flow Switch Panel.	NA	NA	NA
	3. PA system Panel.	NA	NA	NA
	4. Battery backup	NA	NA	NA
	5. Building floor plan	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any :			
<p>The Fire protection systems provided in the building were randomly checked and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/Club2014/SZ/33 dated 10/01/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				
			<p><i>R.N. Singh</i> 29/3</p> <p>Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO</p>	

Renewal

Safdarjung Club, Safdarjung Enclave, New Delhi-29

Div. Officer (SD) *on EL*

dy CEO/S2

752/CFoS
30/3/17

Lamp
28/3



CFoS2

Pl speak about use of basement.

DEFO/S2

30/3

Pl speak

Lamp

11/4