

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/2017/1482

Dated: 10/10/17

FIRE SAFETY CERTIFICATE


Certified that the **Pizza Hut (A Unit of Devyani International Limited)** located at **G - 5, Ground Floor, Aggarwal Millenium Tower, E - 1, 2, 3, Netaji Subhash Place, Pitampura, Delhi - 110034** was issued FSC vide Letter No. F6/DFS/MS/EH/2014/374 dated 10-09-2014. The Aggarwal Millenium Tower, E - 1, 2, 3, Netaji Subhash Place, Pitampura, Delhi - 110034 has already issued FSC vide letter no. F6/DFS/MS/2017/WZ/931 dated 28-06-2017. The premises was re inspected by the officers concerned of this department on 18-09-2017 in the presence of Ms. Anu (Shift Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly" Group D with effect from 10/10/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on10/10/17... at New Delhi by.


(Atul Garg),
Chief Fire Officer
Delhi Fire Service.

Copy to:

1. Deputy Health Officer (Civil Line Zone),
Public Health Department (NDMC),
16, Rajpur Road, Delhi - 110054.
2. Manager (Pizza Hut),
G - 5, Aggarwal Millenium Tower, E - 1, 2, 3,
Netaji Subhash Place, Pitampura, Delhi - 110034.


10/10/17

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: Pizza Hut (A Unit of Devyani International Limited), G – 5, Ground Floor, Aggarwal Millennium Tower, E – 1, 2, 3, Netaji Subhash Place, Pitampura, Delhi – 110034
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Situated in Building already issued FSC vide letter no. F6/DFS/MS/2017/WZ/931 dated 28-06-2017)
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/14/WZ/374 dated 01-04-14
5. Fire Safety directives Letter No. : FSC Issued to the Building
6. Date of inspection : 18-09-2017
7. Name of the Inspecting Officer : Do/w & ADO (WP)
8. Name and designation of Officer
from the building side : MS. Anu (Shift Manager)
9. Year of Construction : 2003
10. Applicant's letter No. ; Nil dated 10-08-2017

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	60m Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2Exit	114,80 cm	MR(Old Case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	02 nos. each type	Provided	MR
	• Types	DCP, CO2 & WCO2	Provided	MR
	• IS marking	ISI marked	Provided	MR

7. Automatic fire detection and alarming system				
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided at entrance	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	MR
10. Automatic Sprinkler System				
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11. Internal Hydrants: Common with the Building				
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	1	Found Provided	MR
	• Hose Box	Required	Found Provided	MR
12. Yard Hydrants				
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13. Pumping Arrangements: Common with the Building				
	• Ground Level			
	• Discharge of main pump	NA	2850 lpm	MR
	➤ Head of main pump	NA	75m	MR
	➤ Number of main pumps	NA	2	MR
	➤ Jockey pump out put	NA	220 lpm	MR
	➤ Jockey pump head	NA	75m	MR
	➤ Standby Pump out put	NA	Provided	MR
	➤ Standby Pump Head	NA	Provided	MR
	➤ Auto Staring/Manual stopping	NA	Provided	MR
	➤ Pump House Access	NA	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 lpm	Not Provided	MR(Pump at GF are higher side)
	➤ Head of the pump			
➤ Power supply	40 m	Not Provided	MR	
➤ Auto starting of pump	Required	Not Provided	MR	
		Required	Not Provided	MR
14. Captive water Storage for fire fighting: Common with the mall				
	• Under ground tank capacity	NA	2,00,000 litres	MR
	➤ Draw off connection	NA	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10, 000 litres	30, 000 Litres	MR
		Provided		
15	Exit Signage	Required	Provided	MR
16. Provision of Lifts				
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby			

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F6/DFS/MS/EH/14/WZ/374 dated 01-04-14 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~

Name Uday Vir Singh

Designation ADO/WP

Signature of the Inspecting Officer

Name Sh. Mukesh Kumar

Designation DO/W

~~Dy. CFO (WZ)~~
~~CFO West~~
Alidh

31/1/19

FI Pls