

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO.DFS/MS/ 2017/w2 /1475

Dated: 10/10 /2017

FIRE SAFETY CERTIFICATE

Certified that the **M/s Meet Sales Corporation, Plot No.80, PKT-D, Sector-2 DSIDC Bawana, Delhi- 39** comprised of **Basement + ground + one upper floor** owned/occupied by that **M/s Meet Sales Corporation** have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010, and verified by the officer concerned of Fire Service on **26/09/2017** in the presence of **Sh. Davinder Singh Bedi** and that the building /premises is fit for occupancy **Industrial G-2(ii)** building with effect from **10/10 /2017** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The use of basement shall be in accordance with building bye laws
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on.....10.10.17.....at New Delhi.


(Atul Garg)
Chief Fire Officer
Ph: 011-23414250

Copy to:-

1. M/s Meet Sales Corporation, Plot No.80, PKT-D, Sector-2 DSIDC Bawana, Delhi- 39
2. K.C.Arrarwal, DY. Drugs Controller & Licensing Authority, Govt. of National Capital Territory of Delhi, F-17, Karkardooma, New Delhi-110032

INSPECTION REPORT


B+Gr.+1

Mazzanine floor is closed

1. Name & address of the building : M/s Meet Sales Corporation, Plot No.80, PKT-D, Sector-2 DSIDC Bawana, Delhi- 39
2. Type of Occupancy : Industrial G-2(ii)
3. Type of Case : New Case
4. Details of previous NOC : Letter No. Nil Dated: Nil
5. Fire Safety directives letter No : DFS Act 2007 & Rule 2010/ NCB Part IV
6. Date of inspection : 26/09/2017
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers
from the building side : Sh. Davinder Singh Bedi
9. Year of Construction : 2010
10. Applicant's letter No. : F.NW-28/17/CM/3304 dated 04/09/2017

Plot Area: 150 sq m **Covered Area:** B-150 sq m, Gr-110 sq m, FF-110 sq m, **Total-370 Sq m²**

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9.00 mtr	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	1.25 mtr each	1.35 & 1.50 mtr	MR
	• Basements	1.25 & 1.0 mtr	1.25 & 1.0 mtr	MR
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.00 mtr	1.10 mtr	MR



3	Compartmentation.	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust fan & natural ventilation —	MR <i>SL</i>
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	07 ABC ISI marked	07 ABC Yes	M/R M/R M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	M/R M/R M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A N/A N/A N/A N/A	Provided N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA	N/A	Provided	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required Required N/A	Provided Provided N/A	MR MR N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A

Handwritten signature

12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	N/A	N/A	N/A
	➤ Discharge of pump	900 LMP	900 LMP Provided	MR
	➤ Head of the pump	40 m	40 m Provided	MR
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A

Handwritten signature

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..nil...

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

so (nw) on leave
DC F (W2)
~~cto west~~
10/10/17
FTDC

[Signature]
8/10/17

Alankar
28/9/17
AOO (BW)

Any MW
CFOW2
10/10/17
AI is put up for sign. please
10/10/17
AOO (BW)