

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/School/2017/ ND2/1455

Dated: 06/10/17

**FIRE SAFETY CERTIFICATE**

Certified that the EDMC Nigam Paratibha Vidyalaya at Vishwakarma Nagar-I, Jhilmil, Delhi-110095, comprised of ground plus one upper floor, owned/occupied by EDMC Primary School was issued FSC vide letter No. F6/DFS/MS/School/2014/NDZ/16 dated 03/01/14. The school building was re-inspected by the officer concerned of this department on 13/09/2017 in the presence of Mr. V. P. Singh, Teacher of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No-F16/Estate/CC/FireSafety/2011/3298to3398 dated 01/03/11 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' for ground floor with effect from 06/10/17 for a period of **three** years, subject to conditions, printed overleaf.

Issued on 06/10/17 at New Delhi by

lk  
3/10  
(Vipin Kental)  
Chief Fire Officer

To,  
The Principal,  
EDMC Nigam Paratibha Vidyalaya,  
Vishwakarma Nagar-I,  
Jhilmil,  
Delhi-110095

Copy:-  
The Director of Education, EDMC,  
Udyog Sadan, Plot No.419, FIE,  
Patparganj Industrial Area, Delhi-110092

ok  
ly

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.



## INSPECTION REPORT

- 111
1. Name & address of the building : E.D.M.C Primary Pratibha Vidhyalaya,  
Vishwakarma Nagar-I, Delhi -110095.
  2. Building is comprised of : Two separate block (G & G+1)
  3. Type of Occupancy : Educational
  4. Type of Case : Renewal
  5. Details of Previous NOC letter : F6/DFS/MS/School/2014/NDZ/16 dt 03/01/14
  6. Fire Safety direction letter No : F16/Estate/CC/Fire Safety/2011/3298to3398  
Dated 01/03/11
  7. Date of Inspection : ~~19/08/2017~~ 13/9/17
  8. Name of the Inspecting officers : ADO V. B. Yadav
  9. Name and designation of Officer:  
from the building side : Mr. V. P. Singh (Teacher)
  10. Year of Construction : Ground floor-1979 & first floor-2011
  11. Applicant's letter No : Letter No.-Nil, Dated-16/08/17

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 mtr.	09 mtr.	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	01 Nos.	02 Nos.	MR
		N/A	N/A.	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	1.50 mtr.	1.50 mtr. each	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
		01 Nos.	02 Nos.	MR
	e. Width of Corridor	1.50 mtr.	1.60 mtr.	MR
	f. Door Size	1.00 Mtr.	1.00 mtr.	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A



4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	08 nos.	08 nos.	MR
	• types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A




N/13

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection. The shortcoming communicated vide letter no. F6/DFS/MS/School/2017/NDZ/1411 dated 30/05/17 have been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the circular no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11, it is recommended to issue Fire Safety Certificate.


  
 Signature of the Inspecting Officer  
 Name :- Vijay Bahadur  
 Designation :- A.D.O (T. Pur)

DO(ED)

Submitter for approval plan.

DYCMO/MS.

  
15/9

  
15/9/17

247/CR/MS  
19/9/17

C.F.P.

M.Scell 16/19

As approved FT letter is put up for signature please.

