

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2017/SZ/ 1544

Dated: 27.10.17

**FIRE SAFETY CERTIFICATE**

Certified that the **Vidya Niketan Primary School** located at **D-Block, Saket, New Delhi-110017**, comprised of **basement, ground plus two upper floors** was granted NOC by this department vide letter No. F6/DFS/MS/2005/387 dated 23/02/2005. The premises was re-inspected by officer concerned of this department on 04.10.2017 in the presence of Mrs. Anandita Dass (Principal) of the school and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27.10.17..... at New Delhi by

*VK*  
*23/10*  
(Vipin Kental)  
Chief Fire Officer  
Ph: 011-23412225

**Copy to: -**

1. The Principal, Vidya Niketan Primary School, D-Block, Saket, New Delhi-110017
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

INSPECTION REPORT				
1	Name & Address of the Building	VIDYA NIKETAN PRIMARY SCHOOL, D-BLOCK, SAKET, NEW DELHI-110017		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Basement, Ground + 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2005/387 Dated 23/02/2005		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2004/394 dated 19/2/2004		
7	Date of Inspection	04/10/2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mrs. Anandita Dass (Principal)		
10	Year of construction	2004		
11	Applicant letter No.	Nil Dt 7.07.2017, ODD No. 11506 Dt. 19/09/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Accessible	9 m	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a. Number of Staircase</b>			
	1. Upper floors.	2 No's	Provided	MR
	2. Basement floor.	2 No's	Provided	MR
	<b>b. Width of Staircase</b>			
	1. Upper floors	1.5 mtr	1.30 mtr each	MR(old case)
	2. Basement floor	1.5 mtr	1.30 mtr each	MR(old case)
	<b>c. Protection of exits</b>			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	<b>d. No. of continuous staircase to terrace</b>	Required	One	MR
	<b>e. Width of corridor</b>	NA	NA	NA
	<b>f. Door size</b>	NA	1 mtr	NA
3	<b>Compartmentation.</b>			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	<b>Smoke Management system.</b>			
	• Basement	Required	Exhaust Fan provided	MR
	• Upper floors	NA	NA	NA
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	10 No's	13 No's	MR
	• Types	ABC / Co2	ABC- 13	MR
	• ISI Marking	Required	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	1. Total numbers on each floor.	One	Provided	MR
	2. Length of hose-reel hose.	30 mtr	Provided	MR
	3. Nozzle Diameter	5 mm	Provided	MR

7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	<b>MOEFA / SIREN</b>	NA	NA	NA
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Size of Riser/Down-comer</li> <li>• Number of Hydrant per floor</li> <li>• Hose box.</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants.</li> <li>• Hose box.</li> </ul>	NA	NA	NA
		NA	NA	NA
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li>• <b>Ground Level</b> <ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> <li>➤ Head of main pump.</li> <li>➤ Number of main pumps.</li> <li>➤ Jockey Pump output.</li> <li>➤ Jockey Pump head.</li> <li>➤ Standby Pump output.</li> <li>➤ Standby Pump head.</li> <li>➤ Auto Starting / Manual Stopping.</li> <li>➤ Pump house access.</li> </ul> </li> <li>• <b>Terrace Level</b> <ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> <li>➤ Head of pump.</li> <li>➤ Power supply.</li> <li>➤ Auto starting of pump.</li> </ul> </li> </ul>			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 & 180 LPM	900 & 180 LPM	MR
		40 mtr	40 mtr	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity. <ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> <li>➤ Fire Service Inlet.</li> <li>➤ Access to tank.</li> </ul> </li> <li>• Overhead tank capacity.</li> </ul>	25,000 ltrs	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 Ltr	10,000ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft.</li> <li>• Pressurization of lift lobby.</li> <li>• Communication in lift car.</li> <li>• Fireman's switch.</li> <li>• Lift signage.</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	<b>Standby Power Supply</b>	NA	NA	NA
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	NA	NA	NA
		NA	NA	NA

19.	<b>Fire Control Room.</b>	• Detector system panel.	NA	NA	NA
		• Flow switch panel.	NA	NA	NA
		• PA system panel.	NA	NA	NA
		• Battery backup.	NA	NA	NA
		• Building floor plan.	NA	NA	NA
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	NA	NA	NA	

The Fire protection systems provided in the building were checked /operated and found functional at the time of inspection. Shortcomings communicated by this department vide letter dated 06/06/17 found complied.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/2005/387 dated 23.02.2005, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*R.N. Singh*  
12/11/17

Signature of the Inspecting Officer  
Name : R.N. Singh  
Designation: ADO

Vidya Niketan Primary School, D-Block, Saket, New Delhi-110017

DO (SD)  
*Anilash*  
13/11/17

*Dy. CP (CS)*

1208/CP 82  
18/11/17

*lap*  
13/11

*CP (CS)*

*M. S cell*  
*FTR*  
*17/10*

RT letter is put up for signature of *R.N. Singh*  
18/11

*CP (CS)*  
*M. S cell*  
*23/10*

