

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/EH/2017/SZ/ 1583

Dated: 7/11/17

**FIRE SAFETY CERTIFICATE**

Certified that the **Hao Shi Nian Nian** located at **M-25, Greater Kailash-II, New Delhi-11048** comprised of **Basement, Ground + 3 upper floor** and the restaurant running on ground + 2 upper floors was issued FSC by this department vide letter No. F.6/DFS/MS/EH/2012/4612 dated 13/12/2011. The restaurant premises was re-inspected by the officer concerned of this department on 24/10/2017 in the presence of Mr. Tushar (Director) of the restaurant and found that restaurant in the name and style of M/s **Karma Kismat** (Unit of Gaurika Hotels & Restaurants Pvt. Ltd) running at first & second floor of said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class-D "**Assembly Building**" (Eating House) as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 7/11/17 at New Delhi by

*Revised*  
*24/11/17*

*7/11*  
(Vipin Kental)  
Chief Fire Officer  
Tel: 011-23412225

Copy to: -

1. The DHO (CZ), South MCD, Health Deptt, Central Zone, Lajpat Nagar, New Delhi-24
2. M/s Karma Kismat Restaurant at FF & SF, M-25, Greater Kailash-II, New Delhi-110048

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."



## INSPECTION REPORT

1	Name & Address of the Building	M/s KARMA KISMAT RESTAURANT located at M-25, FF & SF, Greater Kailash-II, New Delhi-48 (Unit of Gaurika Hotels & Restaurants Pvt. Ltd)		
2	Type of Occupancy	Assembly buildings 'Group-D'		
3	Building comprised of	Basement, Ground plus Three upper floors.		
4	Type of Case	Renewal & Change of name		
5	Details of Previous NOC	F.6/DFS/MS/EH/2012/4612 dated 13/12/2012		
6	Fire Safety Directives Letter No.			
7	Date of Inspection	24-10-2017		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Tushar (Director)		
10	Year of construction	Restt running only at 1 <sup>st</sup> & 2 <sup>nd</sup> floor of the bldg		
11	Applicant letter No.	DHO/SZ/2017/D-1224 dated 13.09.2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC/ Circular -2005 requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Required	6 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits</b>			
	<b>a. Number of Staircase</b>			
	• Upper floors	Required	Two	MR
	• Basement floor	N/A	Two	N/A
	<b>b. Width of Staircase</b>			
	• Upper floors	Required	1.30m & 0.93m	MR
	• Basement floor	N/A	1.30m & 0.93m	N/A
	<b>c. Protection of exits</b>			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	One	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size / Exits</b>	Required	1.10m & 0.86m	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	<b>Smoke Management system.</b>			
	• Basement	N/A	Exhaust fan provided	N/A
	• Upper floors	Required	Exhaust fan provided	MR
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	8 No's	8 No's	MR
	• Types	ABC / Co2	ABC-04, Co2-04	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

M/s Karma Kismat Restt situated at FF &amp; SF, M-25, Greater Kailash-II, New Delhi-48



7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	<b>MOEFA/MCP's</b>	Required	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	N/A	100 mm	N/A
	• Number of Hydrant per floor	N/A	One	N/A
	• Hose box.	N/A	One	N/A
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	450 & 180 LPM	450 & 180 LPM	MR
	➤ Head of pump.	35 mtr	35 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 ltrs	10,000 ltrs	MR
		Required	Provided	MR
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	Required	Provided	MR
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

19.	<b>Fire Control Room.</b>			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any :</b>	N/A	N/A	N/A
<p>The Fire protection systems provided in the building were checked / operated and found functional at the time of inspection.</p> <p>Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/2012/4612 dated 13/12/2012, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p> <p style="text-align: right;"><i>R.N. Singh</i> 25/11/17</p> <p style="text-align: right;">Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO (BCP)</p>				

M/s Karma Kismat Restt situated at FF & SF, M-25, Greater Kailash-II, New Delhi-48

DO (SD)

*Anil*  
25/11/17

*By. CPO/820*

*Ramp*  
25/11



1323/Chase  
30/11/17

*UFO/Sp*

*M.S. Chauhan*

*Ue*  
30/10

F.T letter is put up for sign. ple. *R.N. Singh*  
03/11

*CPO/Sp*

*M.S. Chauhan*

*Ue*  
7/11