

FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F-6/DFS/MS/School/2017/ *W2/1584*

Dated: *07/11/2017*

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Pry. School** Located at **G- Block Shakurpur JJ Colony Delhi-110034**. comprised of **02 Block (BL-1= Ground Floor & BL-2= G + 1 Upper Floor)** owned and occupied by **M.C. Pry. School** have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011/ issued by the Director of Education and verified by the officers concerned of Fire Service on **17-10-2017** in the presence of **Ms. Samita Aggarwal (Principal)** and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B - 1 with effect from *.07./11./17*... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on*07./11./17*.... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:-

**The Principal,
M.C. Pry. School, G- Block Shakurpur JJ Colony Delhi-110034.**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the exit & wired door provided at corridor must be kept open & free from any obstructing.

INSPECTION REPORT

1. Name & address of the building: **M.C. Pry. School Located at G- Block Shakurpur, JJ Colony Delhi-110034.**
 2. Type of Occupancy : Educational 02 Block (BL-1=Ground Floor &BL-2=G + 1 Upper Floor)
 3. Type of Case : New
 4. Details of previous NOC : Nil
 5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
 6. Date of inspection : 17-10-2017
 7. Name of the Inspecting Officer : Udai vir singh, ADO (WP)
 8. Name and designation of Officer from the building side : Ms. Samita Aggarwal (Principal)
 9. Year of Construction : 2005
10. Applicant's letter No. : AE (M-II)/KPZ/2017-18/85 dated -31/08/2017

No. of Students=218
 No. of class rooms=20
 Plot area=12546.787sqm
 Covered area=1956.8sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided 540cm Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> BL-2=02 NA 	<ul style="list-style-type: none"> Provided NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 150cm NA 	<ul style="list-style-type: none"> BL- 2=1x192,1x155cm NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace			
	<ul style="list-style-type: none"> • 1 		<ul style="list-style-type: none"> Provided 	<ul style="list-style-type: none"> MR
	e. Width Of Corridor			
	<ul style="list-style-type: none"> • 1.5m 		<ul style="list-style-type: none"> 215cm Provided 	<ul style="list-style-type: none"> MR
	f. Door Size			
	<ul style="list-style-type: none"> • 1 mtr 		<ul style="list-style-type: none"> 111cm Provided 	<ul style="list-style-type: none"> MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 07nos. ABC & CO₂ ISI marked 	<ul style="list-style-type: none"> 07 Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Power supply 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto starting of pump 	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA

