

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No: F6/DFS/MS/SCHOOL/2017/ W2 / 1599

Dated: 9 / 11 / 2017

FIRE SAFETY CERTIFICATE

Certified that the building of **Sarvodaya Kanya Vidyalaya No-2**, located at **Tagore Garden New Delhi-110027** comprised of (**BL-1= Ground Floor & BL-2= G+ One Upper floor only**) owned and occupied by **Sarvodaya Kanya Vidyalaya No-2**, have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officers concerned of Fire Service on 13-10-2017 in the presence of Ms. Renu Sethi (Principal) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B - 1 with effect from ...9/11/17... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...9/11/17... at New Delhi.


(Atul Garg)

Chief Fire Officer,
Delhi Fire Service

Copy to:-

1. The Principal,
Sarvodaya Kanya Vidyalaya No-2, Tagore Garden, New Delhi-110027.

Book

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: **Sarvodaya Kanya Vidyalaya** Located at **No-2, Tagore Garden (ID-1515025) New Delhi-110027**
2. Type of Occupancy : Educational (**BL-1= Ground Floor & BL-2=G+ One Upper floor only**)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2015/WZ/1378 DATED-30/07/2015(**Issued for old Block Comprised of G. Floor Only**)
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11
6. Date of inspection : 13-10-2017
7. Name of the Inspecting Officer : Udai vir Singh, ADO (WP)
8. Name and designation of Officer
from the building side : Ms. Ranu Sethi (Principal)
9. Year of Construction : 1970 old & 2015 new
10. Applicant's letter No. : SKV/NO-2/TG/2017/446 dated 13-09-2017

Total Area = 6375 m ²
Covered Area = 4075 m ²
No. of class rooms = 48
Total no. of Students = 1600 /

S No	Minimum standards on fire prevention and fire safety U/R	DOE 3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible Accessible 	<ul style="list-style-type: none"> Provided 570cm Provided Provided 	<ul style="list-style-type: none"> MR MR MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 02 NA 	<ul style="list-style-type: none"> 02 Provided NA 	<ul style="list-style-type: none"> M.R. NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 150 cm NA 	<ul style="list-style-type: none"> 1x156cm & 1x152cm NA 	<ul style="list-style-type: none"> M.R. NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.50cm	175cm Provided	MR
	f. Door Size	1 mtr	103cm Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NR NR NR NR NR 	<ul style="list-style-type: none"> NP NP NP NP NP 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	17 Required	34 Provided	M.R.

6.	First – Aid Hose Reels			
	• Total numbers on each floor	NR	NP	NA
	• Length of hose reel hose	NR	NP	NA
	• Nozzle diameter	NR	NP	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NR	NP	NA
	• Location of Main Panel	NR	NP	NA
	• Location of Repeater Panel	NR	NP	NA
	• Alternate source of power	NR	NP	NA
	• Hooters' Location	NR	NP	NA
8.	MOEFA	NR	NP	NA
9.	Public Address System	NR	NP	NA
10.	Automatic Sprinkler System			
	• Basements	NR	NP	NA
	• Upper Floor	NR	NP	NA
	• Sprinkler above false ceiling	NR	NP	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NR	NP	NA
	• Number of hydrants per floor	NR	NP	NA
	• Hose Box	NR	NP	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NR	NP	NA
	• Discharge of main pump	NR	NP	NA
	➤ Head of main pump	NR	NP	NA
	➤ Number of main pumps	NR	NP	NA
	➤ Jockey pump out put	NR	NP	NA
	➤ Jockey pump head	NR	NP	NA
	➤ Standby Pump out put	NR	NP	NA
	➤ Standby Pump Head	NR	NP	NA
	➤ Auto Starting/Manual stopping	NR	NP	NA
	➤ Pump House Access			
	• Terrace level	NR	NP	NA
	➤ Discharge of pump	NR	NP	NA
	➤ Head of the pump	NR	NP	NA
	➤ Power supply	NR	NP	NA
	➤ Auto starting of pump			
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NR	NP	NA
	➤ Draw off connection	NR	NP	NA
	➤ Fire service inlet	NR	NP	NA
	➤ Access to tank	NR	NP	NA
	• Overhead Tank capacity	NR	NP	NA
15	Exit Signage	NA	NA	NA

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NP	NA
	➤ Pressurization of lift lobby	NR	NP	NA
	➤ Communication in lift Car	NR	NP	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage			
17.	Standby power supply	NR	NP	NA
18.	Refuge Area			
	➤ Total area	NR	NP	NA
	➤ Location	NR	NP	NA
19.	Fire control room			
	➤ Detector system panel	NR	NP	NA
	➤ Flow Switch Panel	NR	NP	NA
	➤ PA System Panel	NR	NP	NA
	➤ Battery backup	NR	NP	NA
	➤ Building Floor Plans	NR	NP	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NP	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2015/WZ/1378 DATED-30/07/2015.renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended

Note;-Earlier the FSC was issued for old Block (comprised of Ground Floor only)

Signature of the Inspecting Officer

Name *Vedant Kumar*

Designation *ASD/CFP*

D/O This is new case. Pl. put up FSC accordingly.

ASD/CFP

Sir necessary correction are made in
DFA.

D/O 27/10/17

D/O 27/10/17

D/O 27/10/17