

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No.F6/DFS/MS/EH/SZ/2017/ 1575

Dated : 3/11/17

FIRE SAFETY CERTIFICATE

Certified that the M/s **The Last Call** (Old name Boom Box Cafe) located at 1st & 2nd Floor of Flat No. 2 & 3, Khan Market, New Delhi. Owned/occupied by A unit of Sukhija Hospitality Pvt. Ltd. has already been issued FSC by this department vide letter No. F6/MS/DFS/EH/2014/SZ/878, dated 17/07/2014. The restaurant was re-inspected by the officer concerned of this department on **17/10/2017** in presence of Mr. Mukesh (owner) and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Assembly Building Group 'D' (Restaurant)** with effect from 3/11/17 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 3/11/17 at New Delhi by.


(Vipin Kental)
Chief Fire Officer
Tel: 011-23412225

Copy to:-

1. Medical Officer of Health, New Delhi Municipal Council, Palika Kendra, New Delhi.
2. M/s The Last Call (A unit of Sukhija Hospitality Pvt. Ltd.), 1st & 2nd Floor of Flat No. 2 & 3, Khan Market, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1. Name & address of the building:- M/S the Last Call(Old Name M/s Boom Box Cafe) A unit of Sukhija Hospitality Pvt. Ltd., 1st & 2nd floor, Flat No. 2& 3, Khan Market, New Delhi.
2. Type of occupancy:- Assembly Building (Restaurant)
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/EH/2014/SZ/878, dt-17/07/14
5. Fire safety directives No.- N/A
6. Date of inspection:- 17/10/17 **(Ground + 2 upper floors)**
7. Name of the inspecting officer:- A.D.O.Mehmood
8. Name & designation of officer
From the building side:- Mukesh (owner)
9. Year of construction:- 2008-09
10. Applicant's letter No:- No. D.446/MOH/Lic./SI-VI dated 11/10/17

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Old NOC (21/04/2011) Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Accessible	06 m.	MR
	2) Gate width	N/A	Directly accessible from the road	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	2 nos.	2 nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.0 m. each	1.0 m. each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 no	Provided.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 m.	(final exit)	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan provided	MR
5.	Fire Extinguishers			

	1) Total numbers	Required	06 No	MR
	2) Types	Required	ABC- 3/ CO ₂ - 3	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	01 no.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	Provided (smoke)	N/A
	2) Location of main panel	N/A	Provided	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	Provided	N/A
	5) Hooter's Location	N/A	Provided	N/A
8.	MOEFA			
		Required	Provided	MR
9.	Public Address System			
		N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	Provided	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required	Provided	MR
	2) Number of hydrants per floor (2 nd floor)	1 No.	1 No.	MR
	3) Hose box	1 No.	1 No.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450, 180 LPM	Provided	MR
	b) Head of pump	Required	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR

H/12

14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	N/A	01 CO ₂ type fire Extinguisher found Provided near electric panel	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

This Department has no objection for changing the name of the restaurant from M/s Boom Box Café to M/s the Last Call located at 1st & 2nd flat no. 2 & 3, Khan Market, New Delhi as changing for name does not have any effect in fire protection arrangement.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures required under the rules. Renewal of Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010, is recommended.

Mehmoed
Mehmoed 23/10/17
Assistant Divisional Officer

~~20/10/17~~
Anilash
24/10/17

20/10/17
21/10/17

20/10/17

