

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2017/SZ/ 1614

Dated: 13-11-17

FIRE SAFETY CERTIFICATE

Certified that the **Satyanam Public School** located at **L-1, Sangam Vihar, New Delhi-110062**, comprised of basement, ground plus two upper floors was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/S/2013/SZ/1368 dated 31/12/2013. The premises was re-inspected by officer concerned of this department on 13.10.2017 in the presence of Mrs. Madhu Sharma (Principal) of the school and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance Director of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13-11-17 at New Delhi by

U. T. J. H.
(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225

Copy to: -

1. The Principal, Satyanam Public School, L-1, Sangam Vihar, New Delhi-110062
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.


INSPECTION REPORT				
1	Name & Address of the Building	SATYANAM PUBLIC SCHOOL, L-1, SANGAM VIHAR, NEW DELHI-110062		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Basement, Ground + 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/S/2013/SZ/1368 dated 31/12/2013		
6	Fire Safety Directives Letter No	DOE Circular No. 262-362 Dated 17/01/2005		
7	Date of Inspection	13-10-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mrs. Madhu Sharma (Principal)		
10	Year of construction	2009	School running at ground and upper floors having total 20 rooms including class rooms & offices.	
11	Applicant letter No.	S-21353/SPS/LB/SV/Fire/2017 dated 28-08-2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6 mtr.	MR
	• Gate width	NA	4.5 mtr	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	1. Upper floors.	2 No's	2 No's	MR
	2. Basement.	NA	NA	NA
	b. Width of Staircase			
	1. Upper floors	1.5 m / 0.75 m	1.60 m & 1.25 m	MR
	2. Basement.	NA	NA	NA
	c. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	One	Two	MR
	e. Width of corridor	NA	NA	NA
	f. Door size	NA	1 mtr	NA
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	Required	Exhaust fans provided	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	09 Nos	09 Nos.	MR
	• Types	ABC / Co2	ABC- 05, Co2-04	MR
	• ISI Marking	ISI Marking	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One	One	MR
	• Length of hose-reel hose.	30 m	30 m	MR
	• Nozzle Diameter	5 mm	5 mm	MR

19.	Fire Control Room.			
	1. Detector system panel.	NA	NA	NA
	2. Flow switch panel.	NA	NA	NA
	3. PA system panel.	NA	NA	NA
	4. Battery backup.	NA	NA	NA
	5. Building floor plan.	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.		NA	One ABC type fire extinguisher provided near electrical panel

The Fire protection systems provided in the building were checked / operated and found functional at the time of inspection. The shortcomings communicated vide letter no. F.6/DFS/MS/School/2017/SZ/294 dated 01/02/2017 has been rectified by school management. ✓

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 17/01/2005, FSC issued vide letter No. F6/DFS/MS/School/2013/SZ/1368 dated 31/12/2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name : R.N. Singh
 Designation: ADO

Satyanam Public School, L-1, Sangam Vihar, New Delhi-62

DO (8D)

Amilash
24/1/17

dy. sp (SZ)

Janf
23/1



1348/cfo/sz
8/11/17

CFO sps

what about short coming at p no 4
of letter dt. 1-2-17.

W
11/1/17

DCFO/SZ

'A' above at N/3 may kindly
be reviewed M.



CFO (S.Z)

FTM.

Janf
7/11