

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2017/SZ/1631

Dated: 14.11.17

FIRE SAFETY CERTIFICATE

Certified that the Shaheed Captain Anuj Nayyar Sarvodaya Bal Vidyalaya No.-2, B-Block Janak Puri, New Delhi-110058, comprised of two blocks namely Old Block & New Block with one Multipurpose Hall. The Old block is having ground floor plus two upper floors and the New block is having ground floor plus one upper floor, owned/occupied by Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2014/SZ/778 dated 24.06.2014. The School building was re-inspected by the officer concerned of this department on 11.10.2017 in the presence of Sh. Dev Singh (Estate Manager) and found that Shaheed Captain Anuj Nayyar Sarvodaya Bal Vidyalaya No.-2 have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....14.11.17..... at New Delhi.

(VIPIN KENTAL)
CHIEF FIRE OFFICER

8/CSom
07/11/17

Copy to:-

1. The Principal,
S C A N Sarvodaya Bal Vidyalaya No.-2,
B-Block Janak Puri, New Delhi-110058
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Comprised of two blocks namely Old Block & New Block. Old block is having ground floor plus two upper floors & New block is having ground plus one upper floor.

INSPECTION REPORT

1. Name & address of the building : Shaheed Captain Anuj Nayyar Sarvodaya Bal Vidyalaya No.-2, B-Block Janak Puri, New Delhi-110058.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2014/SZ/778 dated 24.06.2014
5. Fire Safety directives letter No : N/A
6. Date of inspection : 11.10.2017
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Dev Singh (Estate Manager)
9. Year of Construction : 1980-81 (Old Block) & 2012-13 (New Block)
10. Applicant's letter No. : SCAN/2017/328 dated 19.09.2017

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 24.06.2014	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	09 mtrs Directly accessible from road N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 No.'s in each block	02 No.'s in O-blk 03 no.'s in N-blk	M/R
	b. Width of staircases	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms/additional staircase of 75 cms if less than 150 cms	128 & 128 cms in O blk & 200, 152 & 155 cms in N blk	M/R
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	Two	M/R
	e. Width of Corridor	150 cms	175 cms in O blk & 235 cms in N blk	M/R
	f. Door Size	90 cms in C.rooms & 145 cms in MP hall	90 cms - (double door) in C.rooms & 145 cms in MP hall	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N/A	N/A	N/A
		Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	20 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor for old block 	02 no.'s	Provided	M/R

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	100 mm	N/A
		N/A	Two	N/A
		N/A	Two	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	Two	N/A
		N/A	Two	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		450 LPM (02 no.'s)	Provided	M/R
		30 mtrs	Provided	M/R
		Required	Provided	M/R
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
		10000 ltrs	12,000 ltrs provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			No Lift
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

2/16

19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. Shortcomings issued vide letter no. F.6/DFS/MS/School/2017/SZ/1868 dated 26.07.2017 has been complied.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2014/SZ/778 dated 24.06.2014 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Sandeep
20/10/17

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

[Signature]
23/10/17

DCFO (SZ)

[Signature]

FTW.

[Signature]
3/11

CFO (SZ)

M.S. Ull

F.T letter is put up for signature please.

Sandeep
07/11/17

CFO (SZ)

M.S. Ull

[Signature]
13/11

752/00/SW
23/10/2017



1322/cfo sz
6/11/13/11