

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No.F.6/DFS/MS/School/2017/NDZ/ 1691

Dated: 16/11/17

FIRE SAFETY CERTIFICATE

Certified that the M/S Shaheed Rajpal D.A.V. Public School at Dayanand vihar Delhi - 92, comprised of Basement, Ground plus three upper floor, owned / occupied by Shaheed Rajpal D.A.V. Public School was granted FSC vide letter no. F.6/DFS/MS/SCHOOL/2014/1252 Dated 07/10/14 . The school building was re-inspected by the officer concerned of this department on 31/10/17, in presence of Principal and the school building have deemed complied with the Fire protection and Fire safety requirements in accordance with the circular no. F.16/ Estate/CC/Fire Safety//2011/3298 to 3398 dated 01.03.11 issued by Direct of education and observed that the school building is fit for occupancy class 'B 'Educational Building' for with effect from 16/11/17.... for a period of **three** years, subject to conditions printed overleaf.

Issued on.....16/11/17.....at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,

The Principal
Shaheed Rajpal D.A.V.PublicSchool,
Dayanand vihar Delhi-92.

Copy to:-

The Director of Education
East Delhi Municipal Corporation,
419, Udyog Sadan ,Patparjanj iND. Area
Delhi-110092.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
1. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
2. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
3. This Fire Safety certificate can't be treated in any case for regularizations of unauthorized construction if any.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
5. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : Shaheed Rajpal D.A.V. Public School at
Dayanand vihar Delhi-92.
2. Building is comprised of : Basement, Ground +3, upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/SCHOOL/2014/1252 Dated 07/10/14
6. Fire Safety circular No : Delhi Fire Service Act 2007 and Rule 2010.
7. Date of Inspection : 31/10/17
8. Name of the Inspecting officers : DO F. Brown
9. Name and designation of Officer
10. from the building side : Renu Laroiya (Principal)
11. Year of Construction : 1986
12. Applicant's letter No : SRDAVPS/DV/777 Dated 27/09/2017.

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement <i>as per FSC issued on dt 7-10-14</i>	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	15 Mtrs	MR
	• Gate width	4.5 m	5 m	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 no.	02 no.	MR
	• Basement	02 no.	02 no.	MR
	B. Width of Staircases			
	• Upper Floor	1.5 m	1.5 m each	MR
	• Basement	1.5 m	1.5 m each	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02 no.	02 no.	MR
	g. Width of Corridor	1.5 m	2.0 m	MR
	h. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	22 Nos.	40 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	02 no.	02 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	Provided	N/A
	• size of riser/down-comer	N/A	100mm	N/A
	• Number of hydrants per floor	N/A	01	N/A
	• Hose Box	N/A	01	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	2 No.Provided	MR
	• Hose Box	N/A	2 No.Provided	MR
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	900 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	provided	MR
	➤ Auto Starting of pump	Required	provided	MR
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000Liters	15,000Liters	MR
15	Exit Signage.	Required	provided	MR


16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules.

The Fire safety Certificate issued vide letter no.F.6/DFS/MS/SCHOOL/2014 dated 18/09/2014 has granted, is recommended to renewal Fire Safety Certificate, under rule 35 of the Delhi Fire Service Rule 2010.

submitter please.




Signature of the Inspecting Officer

Name: F. Brown

Designation : DO

DCFO/NDZ



*265/CF-NDR
6/11/13/11*

CF-O. M-scull FT/MT

*UK
3/11*

F. & bellis no prepared and put up for signage plan.

CF/HA

M-scull

*UK
13/11*

