

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/2017/WZ/1646

Dated: 16/11/17

FIRE SAFETY CERTIFICATE

Certified that the **Shiv Modern Public School** located at **Ground + 3 Upper Floors, A-3, Paschim Vihar, New Delhi - 110063** in a building comprised of Basement + Ground + Three Floor was issued FSC vide Letter No. F6/DFS/MS/School/2014/WZ/675 dated 03/06/2014. The premises was re inspected by the officers concerned of this department on 06-11-2017 in the presence of Sh. Sh. PP Singh (Principal). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3268-3368 dated 01/03/2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 16/11/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/11/17..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service

Copy to:

The Principal, Shiv Modern Public School , A-3, Paschim Vihar, New Delhi.8

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used for any purpose.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

Paschim Vihar, New Delhi.

2. Type of Occupancy : Educational (Basement+ Ground + 3 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : F6/DFS/MS/School/2014/WZ/675 dated 03/06/14
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11
6. Date of inspection : 06-11-2017
7. Name of the Inspecting Officer : DO/W & ADO (WP)
8. Name and designation of Officer
from the building side : **Sh. P.P. Singh**
9. Year of Construction : 2000-2001
10. Letter no Nil dated 09/08/2017

No. of Students=585
No. of class rooms=18
Plot area=2603 m ²
Covered area=2000m ²

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMF
1.	Access of building			
	• Road width	06	Provided	MR
	• Gate width	05	362cm Provided	MR
	• Width of internal road	N.R.	N.R.	N.R.
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	NA	1 Provided	NA(Kept Closed)
	b. Width of staircases			
	• Upper floors	1.25 mtr	155cm, 115, Provided	MR
	• Basements	NA	Ramp 210cm, Stair 135cm	NA(Kept close)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	NA	Exhaust Fan Provided	NA
	• Upper floors	Nature Ventilation	NA	NA
5.	Fire Extinguishers			
	• Total numbers	12nos.	15 Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Not Provided	MR

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NR	NR	NR
8.	MOEFA	NR	NR	NR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		NR	NR	NR
		NR	NR	NR
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm	Provided	MR
		1	Provided	MR
		1	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> Detector system panel Flow Switch Panel PA System Panel 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2014/WZ/675 dated 03-06-2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~
~~Name Uday Vir Singh~~
~~Designation IADo/wp~~

~~Signature of the Inspecting Officer~~
~~Name Sh. Mukesh Verma~~
~~Designation Dole~~

~~Signature of the Inspecting Officer~~
~~Name~~
~~Designation~~

~~Signature of the Inspecting Officer~~
~~Name~~
~~Designation~~

FT P/S

~~Signature of the Inspecting Officer~~
~~Name~~
~~Designation~~

Sir AP letter is put up for sign ple.

~~Signature of the Inspecting Officer~~
~~Name~~
~~Designation~~

~~Signature of the Inspecting Officer~~
~~Name~~
~~Designation~~