

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2017/SZ/ 1618

Dated: 13/11/17

**FIRE SAFETY CERTIFICATE**

Certified that the **Sunrise Public School** located at **D-120, Harsh Vihar, Tanki Road, Badarpur, New Delhi-110044**, comprised of **ground plus one upper floor** was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2013/SZ/1265 dated 29/11/2013. The premises was re-inspected by officer concerned of this department on 17.10.2017 in the presence of Mr. Satish Bhati (Manager) of the school and observed addition of two upper floors in exiting school building. The school building now comprised of ground plus three upper floors have complied with the fire prevention and fire safety arrangements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **"Educational Building, Group-B"** as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/11/17 at New Delhi by

*VK*  
*10/11*  
**(Vipin Kental)**  
**Chief Fire Officer**  
**Ph: 011-23412225**

**Copy to: -**

1. The Principal, Sunrise Public School located at D-120, Harsh Vihar, Tanki Road, Badarpur, New Delhi- 110044
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

| INSPECTION REPORT |   |   |                  |                |
|-------------------|---|---|------------------|----------------|
| 1                 | Name & Address of the Building                              | Sunrise Public School, D-120, Harsh Vihar, Bhati Market, Tanki Road, Badarpur, New Delhi-110044 |                  |                |
| 2                 | Type of Occupancy   | Educational Building "Group-B" (School)   |                  |                |
| 3                 | Building Comprised of                                       | Ground + Three upper floors.  |                  |                |
| 4                 | Type of Case  | Renewal & Addition  |                  |                |
| 5                 | Details of Previous NOC                                     | F.6/DFS/MS/School/2013/SZ/1265 Dated 29/11/2013   |                  |                |
| 6                 | Fire Safety Directives Letter No                            |   |                  |                |
| 7                 | Date of Inspection  | 17-10-2017  |                  |                |
| 8                 | Name of the Inspecting Officers                             | R.N. Singh, ADO (BCP)   |                  |                |
| 9                 | Name & Designation of Officers from the building side       | Mr. Satish Bhati  |                  |                |
| 10                | Year of construction  | 2006, 2012-13 & 2015-16   |                  |                |
| 11                | Applicant letter No.  | DFS/No-4 dated 06/10/2017   |                  |                |
| S. No.            | Minimum standards on Fire Prevention and Fire Safety U/R 33 | BBL / NBC Requirement   | Provided at Site | Remarks MR/NMR |
| 1                 | <b>Access to Building.</b>                                  |   |                  |                |
|                   | • Road width  | 6 mtr   | 6 mtr            | MR             |
|                   | • Gate width  | NA  | 4.5 mtr          | NA             |
|                   | • Width of internal road                                    | NA  | NA               | NA             |
| 2                 | <b>Number, width, type &amp; arrangement of exits.</b>      |   |                  |                |
|                   | <b>a. Number of Staircase</b>                               |   |                  |                |
|                   | ➤ Upper floors.   | 2 No's  | 2 No's           | MR             |
|                   | ➤ Basement floor.   | NA  | NA               | NA             |
|                   | <b>b. Width of Staircase</b>                                |   |                  |                |
|                   | ➤ Upper floors  | 1.5 mtr.  | 1.50 m each      | MR             |
|                   | ➤ Basement floor  | NA  | NA               | NA             |
|                   | <b>c. Protection of exits</b>                               |   |                  |                |
|                   | ➤ Fire check door   | NA  | NA               | NA             |
|                   | ➤ Pressurization  | NA  | NA               | NA             |
|                   | <b>d. No. of continuous staircase to terrace</b>            | Required  | One              | MR             |
|                   | <b>e. Width of corridor</b>                                 | NA  | 1.5 mtr          | NA             |
|                   | <b>f. Door size</b>   | 1 mtr   | 1 mtr            | MR             |
| 3                 | <b>Compartmentation.</b>                                    |   |                  |                |
|                   | • Fire check door.  | NA  | NA               | NA             |
|                   | • Sealing of electrical shafts.                             | NA  | NA               | NA             |
|                   | • Fire rating of shaft door.                                | NA  | NA               | NA             |
|                   | • Water curtain   | NA  | NA               | NA             |
|                   | • Fire dampers.   | NA  | NA               | NA             |
| 4.                | <b>Smoke Management system.</b>                             |   |                  |                |
|                   | • Basement  | NA  | NA               | NA             |
|                   | • Upper floors  | NA  | NA               | NA             |
| 5.                | <b>Fire Extinguishers.</b>                                  |   |                  |                |
|                   | • Total numbers   | 8 No's  | 10 No's          | MR             |
|                   | • Types   | ABC / Co2   | ABC-08           | MR             |
|                   | • ISI Marking   | Required  | Provided         | MR             |
| 6.                | <b>First Aid Hose Reels.</b>                                |   |                  |                |
|                   | • Total numbers on each floor.                              | One   | Provided         | MR             |
|                   | • Length of hose-reel hose.                                 | 30 mtr  | Provided         | MR             |
|                   | • Nozzle Diameter   | 5 mm  | Provided         | MR             |

Sunrise Public School, D-120, Harsh Vihar, Bhati Mkt, Tanki Road, Badarpur, New Delhi


|     |  |            |          |    |
|-----|--|------------|----------|----|
| 7   | <b>Automatic fire detection &amp; alarming system.</b> |            |          |    |
|     | • Type of detectors                                    | NA         | NA       | NA |
|     | • Location of Main Panel                               | NA         | NA       | NA |
|     | • Location of Repeater Panel                           | NA         | NA       | NA |
|     | • Alternate source of power                            | NA         | NA       | NA |
|     | • Hooter's location                                    | NA         | NA       | NA |
| 8.  | <b>MOEFA / SIREN</b>                                   | NA         | NA       | NA |
| 9.  | <b>Public Address System</b>                           | NA         | NA       | NA |
| 10. | <b>Automatic Sprinkler System</b>                      |            |          |    |
|     | • Basement   | NA         | NA       | NA |
|     | • Upper floors   | NA         | NA       | NA |
|     | • Sprinkler above false ceiling                        | NA         | NA       | NA |
| 11. | <b>Internal Hydrants.</b>                              |            |          |    |
|     | • Size of Riser/Down-comer                             | NA         | NA       | NA |
|     | • Number of Hydrant per floor                          | NA         | NA       | NA |
|     | • Hose box.  | NA         | NA       | NA |
| 12. | <b>Yard Hydrants.</b>                                  |            |          |    |
|     | • Total number of hydrants.                            | NA         | NA       | NA |
|     | • Hose box.  | NA         | NA       | NA |
| 13. | <b>Pumping arrangements.</b>                           |            |          |    |
|     | • Ground Level   |            |          |    |
|     | ➤ Discharge of main pump.                              | NA         | NA       | NA |
|     | ➤ Head of main pump.                                   | NA         | NA       | NA |
|     | ➤ Number of main pumps.                                | NA         | NA       | NA |
|     | ➤ Jockey Pump output.                                  | NA         | NA       | NA |
|     | ➤ Jockey Pump head.                                    | NA         | NA       | NA |
|     | ➤ Standby Pump output.                                 | NA         | NA       | NA |
|     | ➤ Standby Pump head.                                   | NA         | NA       | NA |
|     | ➤ Auto Starting / Manual Stopping.                     | NA         | NA       | NA |
|     | ➤ Pump house access.                                   | NA         | NA       | NA |
|     | • Terrace Level  |            |          |    |
|     | ➤ Discharge of pump.                                   | 450 LPM    | 450 LPM  | MR |
|     | ➤ Head of pump.  | 40 mtr     | 40 mtr   | MR |
|     | ➤ Power supply.  | Required   | Provided | MR |
|     | ➤ Auto starting of pump.                               | Required   | Provided | MR |
| 14. | <b>Captive water storage for fire fighting.</b>        |            |          |    |
|     | • Underground tank capacity.                           | NA         | NA       | NA |
|     | ➤ Draw-off connection.                                 | NA         | NA       | NA |
|     | ➤ Fire Service Inlet.                                  | NA         | NA       | NA |
|     | ➤ Access to tank.                                      | NA         | NA       | NA |
|     | • Overhead tank capacity.                              | 10,000 Ltr | Provided | MR |
|     |  | Required   | Provided | MR |
| 15. | <b>Exit Signage.</b>                                   |            |          |    |
| 16. | <b>Provision of Lifts.</b>                             |            |          |    |
|     | • Pressurization of lift shaft.                        | NA         | NA       | NA |
|     | • Pressurization of lift lobby.                        | NA         | NA       | NA |
|     | • Communication in lift car.                           | NA         | NA       | NA |
|     | • Fireman's switch.                                    | NA         | NA       | NA |
|     | • Lift signage.  | NA         | NA       | NA |
| 17. | <b>Standby Power Supply</b>                            | NA         | NA       | NA |
| 18. | <b>Refuge Area</b>                                     |            |          |    |
|     | • Total area   | NA         | NA       | NA |
|     | • Location   | NA         | NA       | NA |

|     |  |    |    |    |
|-----|--|----|----|----|
| 19. | <b>Fire Control Room.</b><br><ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul> | NA | NA | NA |
|     |  | NA | NA | NA |
|     |  | NA | NA | NA |
|     |  | NA | NA | NA |
|     |  | NA | NA | NA |
| 20. | <b>Special Fire Protection System for the Protection of special Risk, if any.</b>  | NA | NA | NA |

The Fire protection systems provided in the building were checked / operated at random and found functional at the time of inspection. The shortcomings communicated vide letter No. F.6/DFS/MS/School/SZ/1335 dated 23/05/2017 has been complied by school management.


Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/School/2013/SZ/1265 dated 29.11.2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.


Accordingly DFA is put up for approval and signature please.


  
 Signature of the Inspecting Officer  
 Name : R.N. Singh  
 Designation: ADO (BCP)

Sunrise Public School, D-120, Harsh Vihar, Bhati Mkt, Tanki Road, Badarpur, New Delhi

DO (SD)

  
24/10/17











FTM.



1359/CP-2  
13/11.

FT letter is put up for sign. b.p.



  
07/11

M-s cell 

