

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2017/SZ/ 1661

Dated: ...16/11/17

**FIRE SAFETY CERTIFICATE**

Certified that **Dashmesh Public School** located at Gurdwara Sri Guru Singh Sabha (Regd.), **Gali No-7, Govindpuri, New Delhi-110019**, comprised of **Ground + two upper floors**, having total 09 rooms Owned/Occupied by Gurdwara Management Committee was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2014/SZ/718 dated 12/06/2014. The school premises was re-inspected by officer concerned of this department on 01.11.2017 in presence of Mrs. Surjeet Kaur (Principal) and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class **“Educational Building, Group-B”** as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on .....16/11/17..... at New Delhi by

  
**Chief Fire Officer**  
**Ph: 011-23412225**

**Copy to: -**

1. The Chairman, Dashmesh Public School at Gurdwara Sri Guru Singh Sabha (Regd.), Gali No-7, Govindpuri, New Delhi- 110019
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.”



## INSPECTION REPORT

|       |   |   |                  |                |
|-------|---|---|------------------|----------------|
| 1     | Name & Address of the Building                              | Dashmesh Public School located at Gurdwara Sri Guru Singh Sabha (Regd.), Gali No-7, Govindpuri, New Delhi- 110019 |                  |                |
| 2     | Type of Occupancy   | Educational Building (School)   |                  |                |
| 3     | Building Comprised of                                       | Ground + two upper floors   |                  |                |
| 4     | Type of Case  | Renewal   |                  |                |
| 5     | Details of Previous NOC                                     | F.6/DFS/MS/School/2014/SZ/718 Dated 12/06/2014  |                  |                |
| 6     | Fire Safety Directives Letter No                            | DOE circular No 262-362 dated 17/01/2005  |                  |                |
| 7     | Date of Inspection  | 01-11-2017  |                  |                |
| 8     | Name of the Inspecting Officers                             | R.N. Singh, ADO (BCP)   |                  |                |
| 9     | Name & Designation of Officers from the building side       | Mrs. Surjeet Kaur (Principal)   |                  |                |
| 10    | Year of construction  | 1998  |                  |                |
| 11    | Applicant letter No.  | DPS/GPR/2017/273 dated 14/09/2017   |                  |                |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC requirements  | Provided at Site | Remarks MR/NMR |
| 1     | <b>Access to Building.</b>                                  |   |                  |                |
|       | • Road width  | Required  | 6 mtr            | MR             |
|       | • Gate width  | NA  | NA               | NA             |
|       | • Width of internal road                                    | NA  | NA               | NA             |
| 2     | <b>Number, width, type &amp; arrangement of exits.</b>      |   |                  |                |
|       | <b>a) Number of Staircase</b>                               |   |                  |                |
|       | ➤ Upper floors.   | Required  | 2 No's           | MR             |
|       | ➤ Basement floor.   | NA  | NA               | NA             |
|       | <b>b) Width of Staircase</b>                                |   |                  |                |
|       | ➤ Upper floors  | 1.50m / 0.75m   | 1.0m & 1.35m     | MR             |
|       | ➤ Basement floor  | NA  | NA               | NA             |
|       | <b>c) Protection of exits</b>                               |   |                  |                |
|       | ➤ Fire check door   | NA  | NA               | NA             |
|       | ➤ Pressurization  | NA  | NA               | NA             |
|       | <b>d) No. of continuous staircase to terrace</b>            | Required  | Two              | MR             |
|       | <b>e) Width of corridor</b>                                 | NA  | NA               | NA             |
|       | <b>f) Door size</b>   | 1 mtr   | Provided         | MR             |
| 3     | <b>Compartmentation.</b>                                    |   |                  |                |
|       | • Fire check door.  | NA  | NA               | NA             |
|       | • Sealing of electrical shafts.                             | NA  | NA               | NA             |
|       | • Fire rating of shaft door.                                | NA  | NA               | NA             |
|       | • Water curtain   | NA  | NA               | NA             |
|       | • Fire dampers.   | NA  | NA               | NA             |
| 4.    | <b>Smoke Management system.</b>                             |   |                  |                |
|       | • Basement  | 30 ACPH   | NA               | NA             |
|       | • Upper floors  | 12 ACPH   | NA               | NA             |
| 5.    | <b>Fire Extinguishers.</b>                                  |   |                  |                |
|       | • Total numbers   | 06 No's   | 06 No's          | MR             |
|       | • Types   | ABC / Co2   | ABC- 04, Co2- 02 | MR             |
|       | • ISI Marking   | Required  | Provided         | MR             |
| 6.    | <b>First Aid Hose Reels.</b>                                |   |                  |                |
|       | • Total numbers on each floor.                              | One   | One              | MR             |
|       | • Length of hose-reel hose.                                 | 30 mtr  | 30 mtr           | MR             |
|       | • Nozzle Diameter   | 5 mm  | 5 mm             | MR             |

Dashmesh Public School at Gurdwara Sri Guru Singh Sabha (Regd.), Gali No-7, Govindpuri, New Delhi




|     |  |            |            |    |
|-----|--|------------|------------|----|
| 7   | <b>Automatic fire detection &amp; alarming system.</b> |            |            |    |
|     | • Type of detectors                                    | NA         | NA         | NA |
|     | • Location of Main Panel                               | NA         | NA         | NA |
|     | • Location of Repeater Panel                           | NA         | NA         | NA |
|     | • Alternate source of power                            | NA         | NA         | NA |
|     | • Hooter's location                                    | NA         | NA         | NA |
| 8.  | <b>MOEFA / SIREN</b>                                   | NA         | NA         | NA |
| 9.  | <b>Public Address System</b>                           | NA         | NA         | NA |
| 10. | <b>Automatic Sprinkler System</b>                      |            |            |    |
|     | • Basement   | NA         | NA         | NA |
|     | • Upper floors   | NA         | NA         | NA |
|     | • Sprinkler above false ceiling                        | NA         | NA         | NA |
| 11. | <b>Internal Hydrants.</b>                              |            |            |    |
|     | • Size of Riser/Down-comer                             | NA         | NA         | NA |
|     | • Number of Hydrant per floor                          | NA         | NA         | NA |
|     | • Hose box.  | NA         | NA         | NA |
| 12. | <b>Yard Hydrants.</b>                                  |            |            |    |
|     | • Total number of hydrants.                            | NA         | NA         | NA |
|     | • Hose box.  | NA         | NA         | NA |
| 13. | <b>Pumping arrangements.</b>                           |            |            |    |
|     | • <b>Ground Level</b>                                  |            |            |    |
|     | ➤ Discharge of main pump.                              | NA         | NA         | NA |
|     | ➤ Head of main pump.                                   | NA         | NA         | NA |
|     | ➤ Number of main pumps.                                | NA         | NA         | NA |
|     | ➤ Jockey Pump output.                                  | NA         | NA         | NA |
|     | ➤ Jockey Pump head.                                    | NA         | NA         | NA |
|     | ➤ Standby Pump output.                                 | NA         | NA         | NA |
|     | ➤ Standby Pump head.                                   | NA         | NA         | NA |
|     | ➤ Auto Starting / Manual Stopping.                     | NA         | NA         | NA |
|     | ➤ Pump house access.                                   | NA         | NA         | NA |
|     | • <b>Terrace Level</b>                                 |            |            |    |
|     | ➤ Discharge of pump.                                   | 450 LPM    | 450 LPM    | MR |
|     | ➤ Head of pump.  | 40 mtr     | 40 mtr     | MR |
|     | ➤ Power supply.  | Required   | Provided   | MR |
|     | ➤ Auto starting of pump.                               | Required   | Provided   | MR |
| 14. | <b>Captive water storage for fire fighting.</b>        |            |            |    |
|     | • Underground tank capacity.                           | NA         | NA         | NA |
|     | ➤ Draw-off connection.                                 | NA         | NA         | NA |
|     | ➤ Fire Service Inlet.                                  | NA         | NA         | NA |
|     | ➤ Access to tank.                                      | NA         | NA         | NA |
|     | • Overhead tank capacity.                              | 5,000 ltrs | 5,000 ltrs | MR |
| 15. | <b>Exit Signage.</b>                                   | Required   | Provided   | MR |
| 16. | <b>Provision of Lifts.</b>                             |            |            |    |
|     | • Pressurization of lift shaft.                        | NA         | NA         | NA |
|     | • Pressurization of lift lobby.                        | NA         | NA         | NA |
|     | • Communication in lift car.                           | NA         | NA         | NA |
|     | • Fireman's switch.                                    | NA         | NA         | NA |
|     | • Lift signage.  | NA         | NA         | NA |
| 17. | <b>Standby Power Supply</b>                            | NA         | NA         | NA |
| 18. | <b>Refuge Area</b>                                     |            |            |    |
|     | • Total area   | NA         | NA         | NA |
|     | • Location   | NA         | NA         | NA |

|     |  |          |   |    |
|-----|--|----------|---|----|
| 19. | <b>Fire Control Room.</b><br><ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul> | NA       | NA  | NA |
|     |  | NA       | NA  | NA |
|     |  | NA       | NA  | NA |
|     |  | NA       | NA  | NA |
|     |  | NA       | NA  | NA |
| 20. | <b>Special Fire Protection System for the Protection of special Risk, if any.</b>  | Required | ABC type fire extinguisher provided near electrical panel | MR |

The Fire protection systems provided in the building were checked /operated at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/School/2014/SZ/718 dated 12.06.2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.


Accordingly DFA is put up for approval and signature please.


  
 Signature of the Inspecting Officer  
 Name : R.N. Singh  
 Designation: ADO (BCP)

Dashmesh Public School at Gurdwara Sri Guru Singh Sabha (Regd.), Gali No-7, Govindpuri, New Delhi

DO (SD)

  
8/11/17

  
CFO/S20


  
9/4




CFO S20

M.S. Saini


FT 101

  
13/11

1392/cfo sl  
16/11

FT letter is put up for sign-ple.   
15/11

CFO/S2 on leave

  
16/11/17