

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2017/ 1626

Dated: 14/11/17

FIRE SAFETY CERTIFICATE


Certified that **G.D. Salwan Public School located at Rajendra Nagar, New Delhi-110060**, having three blocks namely Old Block, Admin. Block & Montessori Block. Old Block is comprised of ground plus two upper floors, Admin Block is comprised of ground and first floor and Montessori Block is comprised of ground plus two upper floors. The FSC was issued for Old Block only by this department vide letter No. F.6/DFS/MS/School/2013/283 dated 08.05.2013. The school building was re-inspected by the concerned officer of Delhi Fire Service on 06.09.2017 in the presence of Ms. Mukul Jha, principal of the school and found that the school management have complied with the fire prevention and fire safety requirements in accordance with Delhi Fire Service Act 2007 and Rules 2010 and that the school complex (Old Block, Montessori Block & Admin Block) is fit for occupancy class "Educational" with effect from 14/11/17 for a period of 03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions printed overleaf under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/11/17 at New Delhi by.


(VIPEN KENTAL)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Principal,
G.D. Salwan Public School,
Rajendra Nagar, New Delhi- 110060.
2. The Directorate of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi- 110054.


92 03/11/2017

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : G.D. Salwan Public School, Rajender Nagar, New Delhi-60
2. Type of Occupancy : Educational
3. Type of Case : Renewal/ New Case
4. Details of previous NOC : F.6/DFS/MS/2013/School/283 dated 08.05.2013 (old block)
5. Fire Safety directives letter No : N/A
6. Date of inspection : 06.09.2017
7. Name of the Inspecting Officers : M.K. Chattopadhyay, Divisional Officer (South West)
8. Name and designation of officers
from the building side : Ms. Mukul Jha, Principal
9. Year of Construction : 1998/ 2014 (construction of two new blocks)
10. Applicant's letter No. : F.2(1)/(35)gdsp/2017/7992 dated 08.08.2017.

G.D. Salwan Public School is having three blocks (Old block, Montessori block and Admin block). Two blocks are comprised ground plus two upper floors and one block is comprised of ground and first floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mts 4.5 mts N/A	Provided Provided N/A	MR MR N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 Nos. each block N/A	Provided N/A	MR N/A
	b. Width of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors • Basements 	1.5 mts or less & 0.75 mt N/A	Old Block- 1.30, 1.30 mts Admin- 1.50, 1.15 mts Montessori- 1.60, 1.25 mts N/A	MR N/A
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.5 mts	Old Block- 2.60 mts Montessori- 1.60 mts Admin- N/A	MR
	h. Door Size	1.0 mt.	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain 	N/A N/A N/A N/A	N/A N/A N/A N/A	N/A N/A N/A N/A

4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	N/A Natural ventilation provided	N/A MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	24 nos. ABC, CO ₂ type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Old Block- 02 Nos. Montessori- 01 No. 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system Not required			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put 	--- N/A N/A N/A N/A	----- N/A N/A N/A N/A	----- N/A N/A N/A N/A

	<ul style="list-style-type: none"> ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		----	-----	-----
		450 LPM	Provided	MR
		30 mts	30 mts	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10000 lts.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Not Applicable		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	Provided	----
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

Handwritten signature

The fire protection systems provided in the building were checked and found functional at the time of inspection.

All the shortcomings issued by this department vide letters dated 14.06.2016, 22.08.2016, 15.11.2016, 04.01.2017 and 03.02.2017 have been complied with by the school management.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act-2007 & Rules- 2010.

DFA is put up for approval & signature please

[Handwritten Signature]
11/9/17

Signature of the Inspecting Officer
(M.K. CHATTOPADHYAY)
Divisional Officer, (South West)

DCFO (SZ)

[Handwritten Signature]

CFO SZ

What's floor area of Admn & Montessori block

13/9/17



DCFO SZ

The floor area of Admn. block & Nursery (Montessorian block) is given by the Admn. Incharge of G.D. Salwan public school.

Submitted for information please

651/DO(SW)
dt. 25/10/2017

DCFO (SZ)

[Handwritten Signature]
25/10

[Handwritten Signature]
25/10/2017



F.A.O. 11/10