

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6 DFS/MS/School/2017/SZ/ 1669

Dated:16/11/17

FIRE SAFETY CERTIFICATE

Certified that the **Kapil Model School** located at **C-1st, 57 & 58, Sangam Vihar, New Delhi-110080**, running at ground and first floor of the building comprised of **Ground plus two upper floors** was inspected by the officer concerned of this department on 28/10/2017 in presence of Mr. Sunder Singh (Manager) of the school and found that the said building have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "**Educational Building**" Group-B, as above with effect from the date of issue of this certificate for a period of **Three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/11/17 at New Delhi by


Chief Fire Officer
Tel: 011-23412225

Copy to: -

1. The Manager, Kapil Model School, C-1st, 57 & 58, Sangam Vihar, New Delhi-110080
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	KAPIL MODEL SCHOOL located at C-1 st , 57 & 58, SANGAM VIHAR, NEW DELHI-110080,		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground plus two upper floors.		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298-3398 dated. 01/03/2011		
7	Date of Inspection	28.10.2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Sunder Singh (Manager)		
10	Year of construction	2009	School running at ground and first floor only	
11	Applicant letter No.	SRPS/CMN/DOE/2016 dated 20/12/2016		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6 mtr.	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	➤ Upper floors.	One	Two	MR
	➤ Basement floor.	NA	NA	NA
	b. Width of Staircase			
	➤ Upper floors	1.5 m / 0.75 m	1.05m & 1.02m	MR
	➤ Basement floor	NA	NA	NA
	c. Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	NA	NA	NA
	f. Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	04 Nos.	05 Nos.	MR
	• Types	ABC / Co2	ABC-10	MR
	• ISI Marking	ISI Marking	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	NA	NA	NA
	• Length of hose-reel hose.	NA	NA	NA
	• Nozzle Diameter	NA	NA	NA

Kapil Model School located at C-1st, 57 & 58, Sangam Vihar, New Delhi


7	Automatic fire detection & alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8.	MOEFA / SIREN	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	NA	NA	NA
	• Number of Hydrant per floor	NA	NA	NA
	• Hose box.	NA	NA	NA
12.	Yard Hydrants.			
	• Total number of hydrants.	NA	NA	NA
	• Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting/Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump.	NA	NA	NA
	➤ Head of pump.	NA	NA	NA
	➤ Power supply.	NA	NA	NA
	➤ Auto starting of pump.	NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	NA	NA	NA
	➤ Draw-off connection.	NA	NA	NA
	➤ Fire Service Inlet.	NA	NA	NA
	➤ Access to tank.	NA	NA	NA
	• Overhead tank capacity.	NA	NA	NA
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17.	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

19. Fire Control Room.			
• Detector system panel.	NA	NA	NA
• Flow switch panel.	NA	NA	NA
• PA system panel.	NA	NA	NA
• Battery backup.	NA	NA	NA
• Building floor plan.	NA	NA	NA
20. Special Fire Protection System for the Protection of special Risk, if any.	NA	NA	NA

The Fire protection systems provided in the building were randomly checked/ tested and found functional at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular dated 01/03/2011, it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010


Accordingly DFA is put up for approval and signature please.



 Signature of the Inspecting Officer
 Name : R.N. Singh
 Designation: ADO (BCP)

Kapil Model School located at C-1st, 57 & 58, Sangam Vihar, New Delhi

DO (SD)



8/11/17


15/11/17


9/11


1281/CFB
15/11/16/11






m.s.gell

FTM.


14/11

RT letter is put up for signature 
15/11/17

