

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2017 / <sup>STPM/</sup> 1675

Dated 17/11/17

**FIRE SAFETY CERTIFICATE**

Certified that the **Multi Purpose Hall ( Indoor sports hall)** located at **Delhi University, North Campus, University Enclave, Vishwavidyala Marg, Delhi** comprised of **basement, ground and one upper floor** owned/ occupied by **Delhi University** was issued FSC vide this office letter no F6/DFS/MS/2010/2716 dated 17.09.2010. The premise was re- inspected by the officer concerned of this department on 16.11.2017 in the presence of **Sh. Rajender Singh/ E.E. (Elec.), Jaspal Singh, A.E (E) & Sh. Abhay / J.E. (Elec.)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premise have therefore, deemed complied with the requirement under rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy class Assembly with effect from ..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

**Conditions for the validity of Fire Safety Certificate:**


1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on ..... at New Delhi by

  
(Atul Garg)  
Chief Fire Officer  
Ph-011-23414250

Copy to:-

1. The Executive Engineer (E)  
North Campus , University of Delhi,  
Delhi-1110007.

  
Jaspal Singh  
A.E (E)  
9971526108

**INSPECTION REPORT**

1. Name & address of the building : Multi Purpose Hall, Delhi University, North Campus, Vishwavidyalaya Marg, Delhi.
2. Type of Occupancy : Assambly (B + G+ 01 upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2010/2716 dated : 17.09.2010
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2008/1444 dated 30/05/2008
6. Date of inspection : 16.11.2017
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers :  
from the building side : Sh. Rajender Singh/ E.E. (E) & Sh. Jaspal Singh, A. E. (E)  
Sh. Abhay / J.E. (Elec.)
9. Year of Construction : --
10. Applicant's letter No. : No.UE/3283/DU/(2017-18) dated 13.11.2017

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	12m	18m	MR
	• Gate width	6m	9m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	c. Number of staircases			
	• Upper Floors	08	08	MR
	• Basements	08	08	MR
	d. Width of staircases			
	• Upper Floors	1.50m	1.50 m each	MR
	• Basements	1.50m	1.50m each	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	g. No. of continuous staircases to terrace	02	02	MR
	h. Width of Corridor	NA	NA	NA
	i. Door Size	01m	01m	MR


3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	Required	Provided	MR
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30ACPH	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12ACPH	Provided	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC/CO2	ABC	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	Required	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	06 nos each	06 each floor	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30m	30m	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sprinkler above false</li> </ul>	NA	NA	NA

	ceiling			
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100mm	100mm	MR
	• Number of hydrants per floor	06	06	MR
	• Hose Box	06	06	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	08	08	MR
	• Hose Box	08	08	MR
13	<b>Pumping Arrangements.</b>			
	➤ Ground Level			
	➤ Discharge of main Pump	2290 lpm	2290 lpm	MR
	➤ Head of Main pump	70 m	70 m	MR
	➤ Number of main pumps	02	02	MR
	➤ Jockey Pump out put	450 lpm	450 lpm	MR
	➤ Jockey pump head	70 m	70 m	MR
	➤ Standby Pump out put	2290 lpm	2290 lpm	MR
	➤ Standby Pump Head	70 m	70 m	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	1,00,000 ltr	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>		Required	Provided
				MR

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standard on the fire prevention fire safety required under the rules, FSC issued vide letter no. F.6/DFS/MS/2010/2716 dated 17.09.2010 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

  
 Signature of the Inspecting Officer  
 Name: - Rajesh Kumar  
 Designation:- ADO/RN

Dy Cfo/w2 — on leave

~~Cfo/w2~~  
 PT PLS

As approved PT is put up for your sign pl -

And/v1