

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110 001**

No. F.6/DFS/MS/GH/2017/NDZ/ 1706

Dated 27/11/17

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s Prim Honda Capital Cars Pvt. Ltd. at plot NO.-1 Patparganj Ind. Complex (Near Mother Dairy Road Delhi -92**, have comprised of basement, ground, plus one upper floor respectively. Owned / occupied by M/s Capital Cars Pvt. Ltd., was granted NOC by this department vide letter No.6/DFS/MS/2016/NDZ/1492 dated 28.11.2014. The Premises was re-inspected by officer concerned of this department on 14.11.17 in the presence of Sh. Rajiv Bhati (Manager, Branch) and that the building is fit for occupancy Group G' Industrial have deemed complied with the Fire prevention and Fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 with effect from ~~27/11/17~~ for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on 27/11/2017 at New Delhi by

  
**(Vipin Kental)**  
Chief Fire Officer  
Delhi Fire Service

o/c  
h

1. Name & address of the building : M/s Prime Honda, Capital Cars Pvt. Ltd. at plot no.-1 Patparganj Ind. Complex (Near Mother Dairy Road) Delhi -92,
2. Building is comprised of : Basement, Ground plus one upper floors ,
3. Type of Occupancy : Industrial Building (Show Room)
4. Type of Case : **Renewal**
5. Details of Previous NOC : F.6/DFS/MS/2014/NDZ/1492 dated 28.11.2014
6. Fire Safety direction letter No : F.6/DFS/MS/2013/BP/135 dated. 24.06.13
7. Date of Inspection : 14.11.2017
8. Name of the Inspecting officers : Francis Brown (DO)
9. Name and designation of officer from the building side : Rajiv Bhati (Manager)
10. Year of construction : 2009 - 13
11. Applicant's letter No : Nil dated 25.09.17

S.No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	12 m	30 m	MR
	• Gate width	5 m	5 m	MR
	• Width of internal road	5.5 m	5.5 m	MR
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	2 nos	2 nos	MR
	• Basement	2 nos	3 nos	MR
	B. Width of Staircases			
	• Upper floor	1.25 M	1.25m 1.18m	MR
	• Basement	1.25 M	1.25m 1.18m & 1.2m	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	2 nos	2 nos	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	01 m	01 m	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	sealed	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	required	provided	MR
	• Fire dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	30a/c per hrs	provided	MR
	• Upper floor	12 a/c per hrs	provided	MR
5.	Fire Extinguishers.			
	• Total numbers	15 nos.	20 Nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 no. 30 m 05 mm	01 no. 30 m 05 mm	MR MR MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of main panel</li> <li>Location of repeater panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	Heat/smoke Ground floor Required Battery & DG Set Different location	Smoke provided provided Provided Different location	MR MR MR MR MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>upper floor</li> <li>sprinkler above false ceiling</li> </ul>	Required Required N/A	Provided in entire basement Provided N/A	MR MR N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose box</li> </ul>	100 MM 01 01	100MM 01 01	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose box</li> </ul>	02 02	02 02	MR MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby pump out put</li> <li>Standby pump head</li> <li>Auto starting /manual stopping</li> <li>Pump house access</li> </ul>	2280 lpm 40 mtrs 01 180lpm 40 mtrs 2280 lpm 40 mtrs Auto Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR MR MR MR
	➤ Terrace Level			
	<ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto Starting of pump</li> </ul>	900 lpm 40 pm Auto Required	900 lpm 40 lpm provided Provided	MR MR MR MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	1,00,000 ltrs Required Required Required 20,000ltrs	1,00,000ltrs Provided Provided Provided 20,000ltrs	MR MR MR MR MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.	Only car lift is existing		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication in lift car</li> <li>• Firemen's grounding switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	Required	provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector system panel</li> <li>• Flow switch panel</li> <li>• PA system panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	02 Mechanical trolley of 50 ltrs.	N/A

The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on Fire prevention and Fire safety measures as required under the directive issued by this department vide letter no. F./6/DFS/MS/2013/BP/135 dated 24/06/13. The NOC issued vide letter no. F.6/DFS/MS/2016/NDZ/1492 dated 28.11.2014 and renewal under Rule 35 of the Delhi Fire Service Rules 2010 is recommended to grant Fire safety certificate.

*Francis Brown*  
16/11/17

Signature of the Inspecting Officer  
Name: Francis Brown  
Designation: DO (East)

DCFO (NDZ)

*dh*  
16/11/17  
C.F.O. / 25/11/17 ATPLS

DCFO/NDZ. F.d. is put up for signature  
please.

C.F.O.

m-scell  
27/11