

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

NO. F.6/DFS/MS/EH/2017/ 1685

Dated:- 20/11/2017

FIRE SAFETY CERTIFICATE

Certified that the M/S Fuji Restaurant (A Unit of K House Restaurant Pvt. Ltd.) located at M-41/2, Speed Bird House, Middle Circle Connaught Place, New Delhi, comprised of Basement, Ground floor + Mezzanine Floor + 3 upper floors but restaurant is running and ground & mezzanine floor only was granted FSC by this department vide letter No. F6/DFS/MS/EH/2014/NDZ/1493 dated 28.11.2014. The premises was re-inspected by the officer concerned of this department on 02.11.2017 in the presence of Sh. Anup Singh and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules 2010 and that the premises, is fit for occupancy class Assembly Building Group D (restaurant) with effect from 20/11/17 for period of three years in accordance with Rule 36 unless under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 20/11/17 at New Delhi


Chief Fire Officer
Delhi Fire Service
Ph- 011-23412225

- Copy to:-
1. Medical Officer of Health (Health Department),
NDMC, Palika Kendra, New Delhi.
 2. The licensee
M/S Fuji Restaurant(A Unit of K House Restaurant Pvt. Ltd.),
M/41/2, Speed Bird House, Middle Circle, Connaught Place New Delhi.

Following fire safety directives may be adhered to :-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency.
of smooth and speedy safe evacuation of occupants in case of emergency
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric shall be verified by the concerned building sanctioning authority.
5. The trained fire fighting staff should be available around the clock.
6. This fire safety certificate may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to it expiry.

INSPECTION REPORT

1. Name & address of the building:- M/s Fuji Restaurant (A Unit of K House Restaurant Pvt. Ltd.), M-41/2, Speed Bird House, Middle Circle, Cannaught Place, New Delhi.
2. Type of occupancy:- Group – D Assembly Building
Basement, Gr.+3 upper floors. (Restaurant at ground & mezzanine floor only)
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/DFS/MS/EH/2014/NDZ/1493 dated 28/11/14.
5. Fire safety directives No.- N/A
6. Date of inspection:- 02/11/17
7. Name of the inspecting officer:- D.O. Gurmukh Singh & A.D.O. Manoj Kumar Sharma
8. Name & designation of officer
From the building side:- Sh. Anup Singh.
9. Year of construction:- Old Heritage Building
10. Applicant's letter No:- Nil. dated 14/10/17

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement / Existing Fire Safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	9 mtr.	9 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 no.	01 no.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr. & 1 mtr.	1.50 mtr. & 1.30 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 mtr.	2 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A

h m

4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors (Ground fl.)	12 a/c per hour	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	18 Nos.	20 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01 no.	01 no	MR
	3) Hose box	01 no.	01 no.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM & 280 LPM	MR

	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltrs	10,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the restaurant were tested, checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/EH/2014/NDZ/1493 dated 28/11/14 , renewal under rule35 of the Delhi Fire Service rules 2010, is recommended.

Gurmukh Singh
Divisional Officer
(Signature)
11/11/17

Manoj Kumar Sharma
Assistant Divisional Officer
(Signature)

(Signature)
Dy CAO (NDZ)
15/11/17
F. O. Y
16/11/17
F. O. Y