

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/GH/2017/NDZ/ 1704

Dated 23/11/17

FIRE SAFETY CERTIFICATE

Certified that the M/s Community Hall at plot no.06 karkardooma Institutional Area Delhi -92, comprised of basement, ground, plus two upper floors respectively, owned / occupied by M/s Raj Priya Welfare Society, 107/5-H East Azad Nager, Delhi, was granted NOC by this department vide letter No.6/DFS/MS/2016/NDZ/1295 dated 17.10.2017. The Premises was re-inspected by the officer concerned of this department on 30.10.17 in the presence of Sh. Bal Krishan Juneja (owner) and found that the Assembly building have deemed complied with the Fire prevention and Fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the building comprised ground plus two upper floors with effect from 23/11/17 for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on 23/11/17 at New Delhi by



Chief Fire Officer
Delhi Fire Service

o/c
f

To,

Sh. Bal Krishan Juneja
Plot NO. no-6 Karkardooma Institutional area
Delhi-92

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

DD/Est

1. Name & address of the building : M/s Community Hall at plot no.06 karkardooma Institutional Area Delhi,
2. Building is comprised of : Basement, Ground plus two upper floors ,
3. Type of Occupancy : Assembly, (Community hall)
4. Type of Case : **Renewal**
5. Details of Previous NOC : F.6/DFS/MS/2014/NDZ/1295 dated 17.10.2014
6. Fire Safety direction letter No : F.6/DFS/MS/BP/2014/49 dt. 08.01.04
7. Date of Inspection : 30.10.2017
8. Name of the Inspecting officers : Francis Brown (DO)
9. Name and designation of officer from the building side : Bal Krishan Juneja (Owner)
10. Year of construction : 2004
- 11 Applicant's letter No : Nil dated 25.09.17

S.No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	12 m	24 m	MR
	• Gate width	4.5	4.5m	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02	02	MR
	• Basement	02	02	MR
	B. Width of Staircases			
	• Upper floor	1.5M	1.5M&1.5M	MR
	• Basement	1.5M	1.5M &1.2	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01no	01no	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.5 m	1.5 m	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	sealed	MR
	• Fire rating of shaft door	02hrs	02hrs	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	30a/c per hrs	provided	MR
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	08 nos.	14 Nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 no.	01 no.	MR
		30 m	30 m	MR
		05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooter's location 	Heat/smoke	provided	MR
		Ground floor	Ground floor	MR
		N/A	N/A	N/A
		Battery & DG Set	Provided	MR
		Staircase	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement upper floor sprinkler above false ceiling 	Required	Provided in entire basement	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose box 	100 MM	100MM	MR
		01	01	MR
		01	01	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	01	02	MR
		01	02	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	Required	Provided	MR
	<ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access 	900 LPM	900LPM	MR
		39 M	39M	MR
		01	01	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		<ul style="list-style-type: none"> Terrace Level 		
	<ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto Starting of pump 	450 lpm	450 lpm	MR
		39 Mtrs	39 Mtrs	MR
		Required	provided	MR
		Required	Auto	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	50,000 ltrs	50,000ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		,5,000ltrs	10,000ltrs	MR
		Required	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	MR
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on Fire prevention and Fire safety measures as required under the Rules the NOC issued vide letter no. F.6/DFS/MS/2016/NDZ/1295 dated 17.10.2014 renewal under Rule 35 of the Delhi Fire Service Rules 2010 is recommended to grant Fire safety certificate.

Francis Brown
6/11/17

Signature of the Inspecting Officer
Name: Francis Brown
Designation: DO (East)

DCFO(NDZ)
[Signature]

~~*[Signature]*~~

277/cf No 2
13/11/20/11

CFD/NDZ m.s cell 13/11

F.t. Lella is prepared and put up for signature plan.

~~CFD/NDZ~~
20/11/17

Kindly ensure the ADO should also go for signatua

Francis Brown
17/11/17