

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No: F6/DFS/MS/2017/1700

Dated: 23.11.17

FIRE SAFETY CERTIFICATE

Certified that the building of **Bharati Vidyapeeth's Institute of Management & Research** located at **A - 4, Paschim Vihar, Rohtak Road, New Delhi - 110063** comprised of Basement + **Ground + Three Upper floors** has already issued fire safety certificate vide letter no. **F.6/MS/DFS/2014WZ/1437** dated 21-11-2014. The premises was re - inspected by the officers from this department on dated 14-11-2017 in the presence of Sh. Pramod Patil (Estate Manager) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition and that the building/premises is fit for occupancy class **Educational Building Group B Sub Division B - 2**, with effect from 23/11/2017 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on23.11.17..... at New Delhi.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service
0/1/2
23/11

Copy to:-

1. The Director,
Bharati Vidyapeeth's Institute of Management & Research,
A - 4, Paschim Vihar, New Delhi - 110063.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. The shed on terrace of 4th floor shall not be used for any purpose of teaching & storage.
7. This certificate cannot be treated in any case for regularizations of unauthorized construction.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

During inspection it was observed that one Barasti Floor (Rainy Shed) is constructed on terrace comprising 4 no. class rooms & 2 Office vide letter no. 02/CC/B/WZ/09/I dated 14-01-2009 from MCD. Now, a certificate dated 14/11/2017 submitted by Dr. Vikas Nath, Director, BVIMR indicating that the rainy shed will be not used for any official and residential purpose and no toilet is built in 4th floor. The rainy shed will not be used for any other purpose in future. The same was found sealed during inspection.

INSPECTION REPORT

1. Name & address of the building: Bharati Vidyapeeth's Institute of Management & Research, A - 4, Paschim Vihar, New Delhi - 110063.
2. Type of Occupancy : Educational (Basement + Ground + 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/MS/DFS/2014WZ/1437 dated 21-11-2014
5. Fire Safety directives Letter No. : F.6/DFS/MS/BP/95/131 dated 06-02-1995
6. Date of inspection : 14-11-2017
7. Name of the Inspecting Officer : Mukesh Verma, DO (West)
8. Name and designation of Officer
from the building side : Sh. Pramod Patil (Estate Manager)
9. Year of Construction : 1999
10. Applicant's letter No. : BVIMR/ND/719/2017-18 dated 18-09-2017

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	60 m	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2 stair & 4 ramps	Provided	NA
	b. Width of staircases			
	• Upper floors	1.2 mtr	167 cm, 170cm	MR
	• Basements	1.2 mtr	2X1.5 mtr, 4X 280 cm ramp Provided	MR
	c. Protection of exits			
	• Fire check door			
	• Pressurization	Required in basement	Provided	MR
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1	Provided	MR
	f. Door Size	1.2 m	Provided	MR
		1 mtr	1 mtr Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

	<ul style="list-style-type: none"> Basements Upper floors 	Required	Provided	MR
		NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	32 nos. ABC & CO ₂ ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	2 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	100 mm Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 2X450 lpm 40Mtr Required Required	2X450 lpm 40m NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	1,00,000 litres NA Required Required 30,000Ltr	Provided NA Provided Provided Provided	MR NA MR MR MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift 	NA NA NA	NA NA NA	NA NA NA

	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/MS/DFS/2014WZ/1437 dated 21-11-2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
15/11/17

Signature of the Inspecting Officer
Name Mukesh Verma
Designation DO (West)

[Signature]
15/11/17

[Signature]
17/11/17

[Signature]
17/11/17

RTP/B
DD/W F.T./FSL is put up for signature please.

[Signature]
21/11/17

[Signature]
17/11/17

[Signature]