

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001.**




NO. F6/DFS/MS/EH/2017/SZ 11709

Dated: 29/11/17

**FIRE SAFETY CERTIFICATE**

Certified that the Haldiram Restaurant (A unit of Haldiram Products Private Limited) running in Shop No. GF-5,6,7 at ground floor of a building comprised of two basements, ground plus five upper floors , Plot No.5, City Centre, Sector-12, Dwarka, New Delhi-110075 have complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 & verified by the officers concerned of fire service on 17.10.2017 in presence of Sh. Vinod Tomer (Unit Manager) & Sh. Vijay Bawera (General Manager) and that the building/premises is fit for occupancy "Assembly Building" Group 'D' (Restaurant) with effect from 29/11/17 for a period of **three years**, subject to compliance of the conditions under rule 38 of the Delhi fire service Rules 2010, printed overleaf.

Issued on 29/11/17 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
  


Copy to:-

1. The DHO, SDMC Building, Dhansa Stand, Najafgarh, New Delhi-110043.
2. General Manager, Haldiram Products Private Limited, 19 A, Shivaji Marg, Najafgarh Road, Moti Nagar, New Delhi-110015.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

### INSPECTION REPORT

1	Name & address of the building	Haldi Ram Restaurant ( A unit of Haldiram Products Private Limited) Shop No. GF-5,6,7 at Plot No.5, City Centre, Sector-12 A, Dwarka, New Delhi-110075.		
2	Type of Occupancy	<b>Restaurant (At ground Floor)</b>		
3	Type of case	New		
4	Details of previous NOC	F6/DFS/MS/Mercuntile/2015/SZ/2015 dated 9.11.2015 for entire Building		
5	Fire safety directives letter No	F6/DFS/MS/BP/2012/4026 Dated 26.10.2012 for entire Building		
6	Date of inspection	17.10.2017		
7	Name of the inspecting Officers :	MK Chattopadhyay DO (S/W) S.P.Bhardwaj ADO (DWK)		
8	Name and designation of officers from the building side	Sh. Vinod Tomer (Unit Manager) Sh. Vijay Bawera (General Manager)		
9	Year of construction	2014		
10	Applicant's letter No.	Nil dated 5.9.2017		<b>Restaurant at Ground Floor</b>

**Building Having ground plus five upper floor with two basements**

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
<b>1</b>	<b>Access to building</b>			
	1) Road width	12 Mtrs.	24 Mtrs.	M/R
	2) Gate width	6 Mtrs.	6 Mtrs.	M/R
	3) Width of internal road	6 Mtrs.	6 Mtrs.	M/R
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	4 Nos. Restaurant located at ground floor	4 Nos. (Provided in Mall)	M/R
	2. basements	5 Nos. (for city centre Mall)	4 Nos. Ground to Terrace & 1 No. 2nd basement o Ground floor+2 Ramps	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtrs.	1.5 Mtrs. (For Mall)	M/R
	2. basements	1.5 Mtrs.	1.5 Mtrs. + Ramp 4.5 Mtrs.(For Mall)	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	Required	Provided (For Mall)	MR
	2. Pressurization	Required	Provided(For Mall)	M/R
	<b>d. No. of continuous staircase to terrace</b>	4 Nos.	4Nos. (For Mall)	M/R
	e. Width of corridor	1.5 Mtrs.	1.5 Mtrs.	M/R
	f. Door size	1.5 Mtrs. & 2 Mtrs. in restaurant area	2 Mtrs. ( 4 Nos. for restaurant Area )	M/R

<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	Required	Provided(For Mall)	MR
	2. Sealing of electrical shafts	Required	Provided	M/R
	3. Fire Rating of shaft door	Required	(In Mall)	M/R
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	Required	Provided	M/R
<b>4</b>	<b>Smoke Management System</b>			
	basement		provided(In Mall)	M/R
		Required		
	upper floors / <b>Restaurant</b>		<b>Provided in Restaurant</b>	M/R
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	5 Nos. CO2,ABC	5 Nos.	M/R
	Types	ISI Marked in	CO2 & ABC	M/R
	ISI marking	Restaurant Area	Provided	M/R
<b>6</b>	<b>First-Aid Hose Reels.</b>	Connected with Building's Main systems		
	total numbers on each floor	Required	<b>Provided in Restaurant area</b>	M/R
	Length of Hose reel hose	30 Mtrs.	30 Mtrs.	M/R
	Nozzle Diameter	5 mm	5 mm	M/R
<b>7</b>	<b>Automatic fire detection and alarming system</b>	Connected with Building's main system		
	Type of detectors	Heat & Smoke	Heat & Smoke	M/R
	location of Main Panel	Required	Time office area	M/R
	location of Repeater panel	Required	Engg. Control & office area	MR
	Alternate source of power	Required	UPS	M/R
	hooter's location	Corridor	Provided	M/R
<b>8</b>	<b>MOEFA</b>	Required	Provided	M/R
<b>9</b>	<b>Public Address System.</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	Required	Provided	M/R
	upper floors	Required	Provided	M/R
	sprinkler above false ceiling	Required	Provided	M/R
<b>11</b>	<b>Internal Hydrants</b>	Connected with main building's system		
	Size of riser/down-corner	150 mm	150 mm	M/R
	Number of Hydrants per floor	4 No.	Provided near restaurant area	M/R
	hose Box	Required	Provided near restaurant area	M/R
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	4 Nos.	7 Nos.	MR
	hose box	Required	Provided near restaurant area	MR
<b>13</b>	<b>Pumping arrangements</b>	Connected with Building,s Main systems		
	<b>1. Ground level</b>			
	a. Discharge of main Pump	2850 Lpm.	Provided to Mall	M/R
	b.Head of main pump	88 Mtrs.	Provided to Mall	M/R
	c.Number of main pumps	Two	Two to Mall	M/R
	d.jockey pump out put	280 Lpm.	Provided to Mall	M/R
	e.jockey pump head	88 Mtrs.	Provided to Mall	M/R
	f. Standby Pump output	2850 Lpm.	Provided to Mall	M/R
	g.Stanby Pump head	88 Mtrs.	Provided to Mall	M/R
	h.Auto Starting/Manual stopping	Required	Auto Made to Mall	M/R

20/16

	<b>2.Terrace level</b>			
	a. Discharge of pump	900 Lpm.	900Lpm. In Mall	M/R
	b. head of the pump	40 Mtrs.	40 Mtrs.	M/R
	c. Power supply	Required	Provided	M/R
	d. Auto starting of pump	Required	Provided	M/R
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	1 Lac Lts.	Provided for Mall	M/R
	a. Draw-off connection	Required	Provided for Mall	M/R
	b. fire service inlet	Required	Provided for Mall	M/R
	c. Access to tank	Required	Provided for Mall	M/R
	Over head tank Capacity	10000 Lts.	10000 Lts. For Mall	M/R
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	M/R
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	Required	Provided for Mall	M/R
	b. pressurization of lift lobby	Required	Provided for Mall	M/R
	c. communication in lift car	Required	Provided for Mall	M/R
	d. Fireman's grounding switch	Required	Provided for Mall	M/R
	e. Lift signage	Required	Provided for Mall	M/R
<b>17</b>	<b>Standby power supply</b>	Required	DG Set 500 KVA	M/R
<b>18</b>	<b>Refuge Area.</b>		N/A	
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
<b>19</b>	<b>Fire control room</b>	Connected with Building,s Main systems		
	a. detector system Panel	Required	Provided ( Mall)	M/R
	b. Flow switch Panel	Required	Provided (Mall)	M/R
	c. PA system Panel	Required	Provided (Mall)	M/R
	d. Batter backup	Required	Provided (Mall)	M/R
	e. Building floor plans	Required	Provided (Mall)	M/R
<b>20</b>	<b>Protection of special risks:</b>	Required CO2 fire exting. for electric panel MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view compliance of the minimum standards on fire prevention & fire safety required under the rules, fire safety certificate is recommended under Delhi fire Service Act 2007 & Rules, 2010.

**Note:-** The said restaurant is running at ground floor of a murcuntile building comprised of Two basements, ground plus five upper upper floors. NOC for entire building is already issued vide letter no. F6/DFS/MS/Mercuntile/2015/SZ/2015 dated 9.11.2015.

Accordingly DFA is put up for approval and signature please.

*[Signature]*  
14/11/17  
MK Chattopadhyay DO (S/W)

*[Signature]* 24/11/17  
SP Bhardwaj ADO (Dwarka)

792/DO(SW)  
03/11/2017  
13-11-2017



*[Signature]*  
DFA(SZ)

*[Signature]*  
G/H

*[Signature]*  
CFO(SW)

what's area of restaurant

*[Signature]*  
DFA/SZ

*[Signature]*  
9/11