

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2017 / w2 / 1790

Dated: 11 / 12 / 17

FIRE SAFETY CERTIFICATE

Certified that the M/s The Bank Bar (A Unit of Blue Jay Health & Fitness Pvt. Ltd.) located at LGF-A at Manglam Paradise Mall, Manglam Place, Sec.-3, Rohini, Delhi-110085 in the building comprised of basement, Ground and 05 upper floors owned/ occupied by M/s The Bank Bar (A Unit of Blue Jay Health & Fitness Pvt. Ltd.) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 15.11.2017 in the presence of **Sh Amit Dhankhar, Owner** and that the building/ premise is fit for occupancy Class Assembly for ground floor only with effect from 11/12/17 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on 11.12.17..... at New Delhi by


(Atul Garg)

Chief Fire Officer

Ph-011-23414250

Copy to:-

1. The Dy. Health Officer, North MCD,
Civil Line Zone, Sec-5, Rohini, Delhi-110054.
2. M/S The Bank Bar (A Unit of Blue Jay Health & Fitness Pvt. Ltd.)
LGF-A, Manglam Paradise Mall, Manglam Place, Sec.-3, Rohini, Delhi.

INSPECTION REPORT

1. Name & address of the building : M/s The Bank Bar (A Unit of Blue Jay Health & Fitness Pvt. Ltd.)
LGF-A, Manglam Paradise Mall, Manglam Place, Sec.-3, Rohini
Delhi-110085.
2. Type of Occupancy : Mix (Assembly/ Business) (Lower Ground Floor only)
3. Type of Case : New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : NBC Part 4.
6. Date of inspection : 15/11/2017
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers : Sh Amit Dhankhar, Owner
from the building side
9. Year of Construction : Old
10. Applicant's letter No. : DHO/RZ/2017/1680 dated 31.10.2017

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	12m	MR
	• Gate width	4.5m	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	The Bank Bar at Lower Ground floor only		
	• Upper Floors	NA	NA	NA
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	1.50m	1.50m each	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA

