

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


NO.F6/DFS/MS/School/2017/SZ/ 1766

Dated: 8/12/17

FIRE SAFETY CERTIFICATE

Certified that the Saraswati Shishu Mandir located at Near Dichaon Road Bus Stand, Najafgarh, New Delhi-110043, comprised of ground plus one upper floor was granted NOC by this office vide letter no. F6/DFS/MS/School/2014/SZ/201 dated 6.2.2014. The said building was re-inspected by the officer concerned of this department on 25.11.2017 in presence of Smt. Urmil Gupta (Accountant) and found that premise have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi , and that the building is fit for occupancy class B "Educational building" with effect from...8/12/17.... for a period of **three** years, subject to compliance of the conditions printed overleaf.

Issued on ...8/12/17..... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director (Education) GNCT of Delhi, Old Secretariat, New Delhi.
2. Principal, Saraswati Shishu Mandir located at Near Dichaon Road Bus Stand, Najafgarh, New Delhi-110043.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Saraswati Sishu Mandir, Dichau Road, Najafgarh, New Delhi-110043.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal	Ground floor plus One upper floor	
4	Details of previous NOC	No.F6/DFS/MS/School/2014/SZ/21 dated 6.2.2014		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	25.11.2017		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Smt. Urmil Gupta (Accountant).		
9	Year of construction	2007		
10	Applicant's letter No.	SSMDR/2017 Dated 25.10.2017	(Ground plus one upper floor)	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE CIR. Dated 1.3.2011/ letter dated 6.2.2014	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	12 Mtrs.	MR
	2) Gate width	N/A	Direct Accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs. (Additional staircase of .75 M is required if less than 1.50 M)	1.20 Mtrs. each	MR being old case
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	1 Nos.	Provided	MR
	e. Width of corridor	1.50 Mtrs.	1.60 to 2.00 Mtrs.	MR
	f. Door size	1 Mtr.	100 Cms. Double doors in each class room	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors		N/A	N/A
5	Fire Extinguishers			
	total numbers	8 Nos. CO2 OR ABC ISI Marked	Provided	MR
	Types		Provided	MR
	ISI marking		Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire Extinguisher provided near electric Meter MR			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of minimum standards on fire prevention and fire safety required as per DOE CIR. Dated 1.3.2011, renewal of FSC issued vide letter no.F6/DFS/MS/School/2014/SZ/201 dated 6.2.2014 is recommended.

Accordingly DFA is put up for approval and signature please.

Sony 27/11/17

S.P. Bhardwaj
ADO (Dwarka)

DOJW

866/DO/SW
30/11/2017

[Signature]
30/11/2017

DCFO (\$2)

[Signature]
30/11



1438/dfw
6/12/8/12

Chf sp m/cell u
6/12

FT is put up for signature

Chf/sz
miscell u

[Signature]
21/11/17