

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001




NO. F6/DFS/MS/2017/ SZ/ 1755

Dated: 7/12/17

FIRE SAFETY CERTIFICATE

Certified that Sh. Mool Chand Dua Memorial Society, Plot No.1, Sector-2, Dwarka, New Delhi comprised of ground plus one upper floor owned/occupied by Sh. Mool Chand Dua Memorial Society was granted Fire Safety Certificate vide this office letter no. F6/DFS/MS/2014/SZ/204 dated 11.2.2015. The said building was re-inspected by the officer concerned of this department on 6.1.2015 in presence Sanjay Gupta (representative) and found that the premises have deemed complied fire prevention & fire safety requirements in accordance with rule 33 of the Delhi Fire Service and that the building is fit for occupancy class D "Assembly building" (Temple) with effect from 7.12.17..... for a period of **three** years, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 as printed overleaf.

Issued on 7.12.17..... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Jt. Director (L&I) Bldg. DDA Building Section INA Vikas Sadan, New Delhi.
2. President, Sh. Mool Chand Dua Memorial Society, E-15, Rajouri Garden, New Delhi-110027.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1	Name & address of the building	Sh. Mool Chand Dua Memorial Society, Plot No.1, Dwarka, New Delhi.		
2	Type of Occupancy	Assembly Building "D"		
3	Type of case	Renewal	G+1	
4	Details of previous NOC	F6/DFS/MS/2014/SZ/204 Dated 11.2.2015		
5	Fire safety directives letter No	F6/DFS/MS/BP/2010/1180 Dated 23.4.2010		
6	Date of inspection	21.11.2017		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mr. Snjay Gupta (Representative)		
9	Year of construction	2014	Ground Plus One Upper Floor	
10	Applicant's letter No.	Nil	11.10.2017	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	9 Mtrs.	9 Mtrs.	MR
	2) Gate width	5 Mtr.	5 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5, 1.25 Mtrs.	1.5, 1.25 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 Mtrs.	2 Mtrs.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	6 Nos.	6 Nos.	MR
	Types	Co2 OR ABC	ABC,	MR
		ISI	ISI	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	Required	Provided	MR
	Length of Hose reel hose	36 Mtrs.	36 Mtrs.	MR
	Nozzle Diameter	5 mm.	5 mm.	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	100 MM	MR
	Number of Hydrants per floor	One	One	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements	N/A	N/A	N/A
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM, 180 LPM	450 LPM , 180 LPM	MR
	b. head of the pump	35 Mtrs.	35 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10,000 Ltr	10, 000 Ltrs.	MR
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	DG Set 62KVA	MR

N/9

18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 fire extinguisher provided near electric panel. MR			

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/2014/SZ/204 dated 11.2.2014 is recommended

Accordingly DFA is put up for your approval and signature please.

S.P. Bhardwaj
28/11/17
S.P. Bhardwaj
ADO (Dwarka)

DOS
852/DOS/20
22/11/2017

[Signature]
26/11/17

DCFO (SZ)

[Signature]
28/11



CFO

F I O.

[Faint handwritten notes at the bottom of the page]