

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

NO F6/DFS/MS/2017 / W2/1782

Dated: 11/12/17

FIRE SAFETY CERTIFICATE

Certified that the "Eating House" in the name and style of **M/S Jamuna Lodge Masonic Centre**, located at **1 C Alipur Road, Qudsia Garden, New Delhi-110054** comprised of Ground Floor only owned/occupied by **M/S Jamuna Lodge Masonic Centre** was issued NOC by this department vide letter No F6/DFS/MS/2010/1626 dated 12.06.2010 in the name of Masonic Club, Qudsia Garden, Yamuna Road, Delhi. The premise was re-visited by the officer concerned of this department on 14.11.2017 in the presence of Sh Padam Bisht and observed that the premise has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Rules, 2010 and that the building/premise is fit for occupancy Class D "Assembly" for ground floor only with effect from 11/12/17 for a period of 03 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. **This certificate cannot be treated in any case for regularizations of unauthorized construction.**
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of form "J"[sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on 11/12/17 at New Delhi by


(Atul Garg)

Chief Fire Officer
Ph-011-23414250

Copy to:

1. The Addl Commissioner of Police(Lic.), 1st Floor, Police Station, Defence Colony, New Delhi.
2. M/S Jamuna Lodge Masonic Centre located at 1 C Alipur Road, Qudsia Garden, New Delhi-110054