

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No:

FG/DFS/MS/2017/Cinema/1754

Dated:

07/12/17

FIRE SAFETY CERTIFICATE

Certified that M/s. INOX Leisure Limited (Audi I to IV), located at Patel Nagar, New Delhi, is running on ground to third floor of a building comprised of basement, ground plus four upper floors was granted FSC/NOC by this department vide letter No. F.6/DFS/MS/Cinema/BP/2002/2407 dated 16.12.2002 and was re-inspected by the officer concerned of this department on 02-11-2017 in presence of Sh. Vinay Kaushik (Manager) and found that the said cinema building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010 and that the building/premises is fit for occupancy class assembly (cinema) with effect from 07/12/17 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/12/17 at New Delhi by.


(VIPEN KENTAL)
CHIEF FIRE OFFICER

Copy to: -

1. District Magistrate (West), Old Middle School Building Complex, Rampura, Delhi-35
2. The Addl. C.P. (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.
3. The Manager, INOX Leisure Ltd. (I to IV), Patel Nagar, New Delhi.

However the following directives must be strictly adhered to:

- a. All the fire fighting arrangements as provided in the cinema building shall always be kept in good repair at all times as seen during inspection.
- b. All the employees shall be acquainted with the use & maintenance of fire protection arrangements provided in the cinema building.
- c. Means of escape shall not be kept blocked or bolted from outside & shall be easily open able in case of emergency.
- d. The fire suppression/protection arrangement provided in the premises are the minimize losses if maintained properly.
- e. Any loss of property/ life due to nonfunctional of fire safety measures/ equipments shall be responsibility of management solely.
- f. Cinema slides providing information on fire protection arrangements and means of escape shall be shown before the commencement of each cinema show.

1. Name & address of the building : INOX Leisure Limited, Patel Nagar, New Delhi
1. Type of Occupancy : Assembly
2. Type of Case : Renewal
3. Details of previous NOC : F.6/DFS/MS/Cinema/2016/2382 dated 06-10-2016
4. Fire Safety directives letter No : F.6/DFS/MS/Cinema/BP/2001/770 dated 08.05.2001
5. Date of inspection : 02.11.2017
6. Name of the Inspecting Officers : M.K.Chattopadhyay, D.O (South West)
7. Name and designation of officers from the building side : Sh. Vinay Kaushik (Manager)
9. Year of Construction : 2001
10. Applicant's letter No. : 79/DDMA(W)/LCT/PVR(S.N.)/ 2015 dated 29.09.2017

Inox Cinema is running at ground to third floor of a building comprised of basement, ground and four upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	06 mts	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	04 Nos.	Provided	MR
	• Basements	02 nos. & 02 Ramps	Provided	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	02 mts (03), 1.20 mts (01)	Provided	MR
	• Basements	1.25 each	Provided	MR
	c. Protection of exits	-----	-----	-----
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	02 Nos.	Provided	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	Old case	1.85 mts. each	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	Required	Provided	MR
4	Smoke Management System.			


	Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	• Total numbers	69 nos.	Provided	MR
	• Types	ABC, Water, CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	03 Nos.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Smoke/Heat	Provided smoke & beam detector.	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Near Staircases	Provided	MR
	• Alternate source of power	Required	D.G. set (380, 250 KVA)	MR
	• Hooters' Location	Entire Building	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	Basement to GF-04 each, FF to SF- 03 each	Provided	MR
	• Hose Box	Basement to GF-04 each, FF to SF- 03 each	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	07 Nos.	Provided	MR
	• Hose Box	07 Nos.	Provided	MR
13	Pumping Arrangements			
	• Ground Level	---	-----	-----
	➤ Discharge of main Pump	2850 LPM each	Provided	MR
	➤ Head of Main pump	60 mts. each	Provided	MR
	➤ Number of main pumps	02 Nos.	Provided	MR
	➤ Jockey Pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	60 mts.	Provided	MR
	➤ Standby Pump out put	2850 LPM	Provided	MR

	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> • Terrace level 	----	-----	-----
	<ul style="list-style-type: none"> ➤ Discharge of pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of the pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity 	2,00, 000 lts.	Provided .	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> • Overhead Tank capacity 	30,000 lts	Provided .	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Communication In lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> • Lift Signage 	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Location 	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Flow Switch Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • PA System Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Battery backup 	Required	Provided	MR
	<ul style="list-style-type: none"> • Building Floor Plans 	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	CO ₂ fire extinguishers are provided in elect. Panels.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/Cinema/2016/2392 dated 06-10-2016, renewal under the Delhi Fire Service Act- 2007 & Delhi Fire Service Rules- 2010, is recommended.


DFA is put up for approval & signature please


16/11/2017

Signature of the Inspecting Officer
(M.K. CHATTOPADHYAY)
Divisional Officer (South West)

DCFO (SZ)


17/11

Pl speak 
25/11

DCFO SZ

Spoken, with DOSW.

