

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

NO.F6/DFS/MS/School/2017/SZ/ 1782

Dated: 12/12/17

**FIRE SAFETY CERTIFICATE**

Certified that the J D Public School, RZ-251-B, Street No.1, Durga Park, Nasirpur, New Delhi-110045, comprised of ground plus two upper floor was granted NOC by this office vide letter no. F6/DFS/MS/School/2014/SZ/92 dated 23.1.2014. The said building was re-inspected by the officer concerned of this department on 27.11.2017 in presence of Sh. Pankaj Batra (Manager) and found that premise have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi , and that the building is fit for occupancy class B "Educational building" with effect from.....12.12.17. for a period of **three** years, subject to compliance of the conditions printed overleaf.

Issued on ...12.12.17..... at New Delhi by

  
( Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
  


Copy to:-

1. Director (Education) GNCT of Delhi, Old Secretariat, New Delhi.
2. Head of School, J D Public School, RZ-251-B, Street No.1, Durga Park, Nasirpur, New Delhi-110045.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.



417  
**INSPECTION REPORT**

1	Name & address of the building	J D Public School, RZ-251-B, Sreet No. 1, Durga Park, Nasirpur, New Delhi.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (G+2)		
4	Details of previous NOC	F6/DFS/MS/School/2014/SZ/92 dated 23.01.2014		
5	Fire safety directives letter No	Directorate of Education:F-16/Estate/CC/fire Safety/2011/3298-3398, Dated 1.3.2011		
6	Date of inspection	27.11.2017		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Pankaj Batra (Manager)		
9	Year of construction	2005, 2013		
10	Applicant's letter No.	Nil dated 14.11.2017		
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>DOE CIR. 1.3.2011</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.50 Mtrs.	Direct Accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	1 No.	1 No.	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtrs.	1.5 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	1 No.	1 No.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1Mtr.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
		12 a/c charge		
	upper floors		Natural Ventilation	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	One No. CO2 OR ABC for every 300 Sq.Mtrs.	8 Nos.	MR
	Types	ISI Marked	ABC	MR
	ISI marking		Provided	MR



N/E				
<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	450 Lpm.	450 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Lts.	10000 Ltrs.	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A




2/8

17	Standby power supply	N/A	N/A
18	Refuge Area.	Not Required	
	total area		
	location		
19	Fire control room		
	a. detector system Panel	N/A	N/A
	b. Flow switch Panel	N/A	N/A
	c. PA system Panel	N/A	N/A
	d. Batter backup	N/A	N/A
	e. Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire extinguisher provided near electric meter.		MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements as per DOE CIR. dated 1.3.2011, renewal of FSC issued vided letter no.F6/DFS/MS/School/2014/SZ/92 dated 23.1.2014 is recommended

Accordingly DFA is put up for approval and signature please.

  
**S.P. Bhardwaj**  
 ADO (Dwarka)

DO/SW

[Signature]  
30/11/17

9B/DO/SW  
30/11/2017

DCFO(S2)

[Signature]  
S/P



4133/cfo S  
1939/cfo S2  
8/12/17

cfo S2

m/s cell

FTM.  
U  
5/12

FT is put up for signature please

[Signature] m.s cell U 8/12/17.

[Signature]  
7/12/17