

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001



NO.F6/DFS/MS/School/2017/SZ/ 1805

Dated: 12/12/17

FIRE SAFETY CERTIFICATE

Certified that the M C Primary School, JJ, Hasthsal No.1, New Delhi-110059, comprised of ground plus one upper floor was granted NOC by this office vide letter no. F6/DFS/MS/School/2014/SZ/1516 dated 3.12.2014. The said building was re-inspected by the officer concerned of this department on 25.11.2017 in presence of Sh. Piyarey Lal (Vice Principal) and found that premise have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi , and that the building is fit for occupancy class B "Educational building" with effect from...12/12/17... for a period of **three** years, subject to compliance of the conditions printed overleaf.

Issued on ...12/12/17..... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service


Copy to:-

1. Deputy Director (Education) SDMC, 23rd floor, Civic Centre, Minto Road, New Delhi.
2. Principal, MC Pry. School, JJ Hasthsal No.1, New Delhi-110059.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

| | | | | |
|---------------|--|---|--|-------------------------|
| 2 | Type of Occupancy | Educational Building "B" | | |
| 3 | Type of case | Renewal | Ground floor plus One upper floor | |
| 4 | Details of previous NOC | No.F6/DFS/MS/School/2014/SZ/1516 dated 3.12.2014 | | |
| 5 | Fire safety directives letter No | Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011. | | |
| 6 | Date of inspection | 25.11.2017 | | |
| 7 | Name of the inspecting Officers : | ADO S.P. Bhardwaj | | |
| 8 | Name and designation of officers from the building side | Sh. Piyaray Lal (Vice Principal). | | |
| 9 | Year of construction | 2007 | | |
| 10 | Applicant's letter No. | Nil Dated 25.10.2017 | (Ground plus one upper floor) | |
| S. NO. | Minimum Standards on fire prevention and fire safety U/R 33 | DOE CIR. Dated 1.3.2011/ letter dated 3.12.2014 | Provided at site | Remarks MR / NMR |
| 1 | Access to building | | | |
| | 1) Road width | 6 Mtrs. | 9 Mtrs. | MR |
| | 2) Gate width | N/A | Direct accessible from road | MR |
| | 3) Width of internal road | N/A | N/A | N/A |
| 2 | Number, width Type & arrangement of exits | | | |
| | a. Number of staircases | | | |
| | 1. Upper floors | 2 Nos. | 2 Nos. | MR |
| | 2. basements | N/A | N/A | N/A |
| | b. Width of staircase | | | |
| | 1. Upper floors | 1.50 Mtrs. | 1.50, 1.62 Mtrs. | MR |
| | 2. basements | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircase to terrace | 2 Nos. | Provided | MR |
| | e. Width of corridor | 1.50 Mtrs. | 2.35 Mtrs. | MR |
| | f. Door size | 1 Mtr. | 100 Cms. Double doors in each class room | MR |
| 3 | Compartmentation. | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Sealing of electrical shafts | N/A | N/A | N/A |
| | 3. Fire Rating of shaft door | N/A | N/A | N/A |
| | 4. water curtain | N/A | N/A | N/A |
| | 5. Fire dampers | N/A | N/A | N/A |
| 4 | Smoke Management system. | | | |
| | basement | N/A | N/A | N/A |
| | upper floors | N/A | N/A | N/A |
| 5 | Fire Extinguishers | | | |
| | total numbers | 6 Nos. CO2 OR ABC | Provided | MR |
| | Types | ISI Marked | Provided | MR |
| | ISI marking | | Provided | MR |

| | | | | |
|-----------|---|-----|----------|-----|
| 6 | First-Aid Hose Reels. | | | |
| | total numbers on each floor | N/A | N/A | N/A |
| | Length of Hose reel hose | N/A | N/A | N/A |
| | Nozzle Diameter | N/A | N/A | N/A |
| 7 | Automatic fire detection and alarming system | | | |
| | Type of detectors | N/A | N/A | N/A |
| | location of Main Panel | N/A | N/A | N/A |
| | location of Repeater panel | N/A | N/A | N/A |
| | Alternate source of power | N/A | N/A | N/A |
| | hooter's location | N/A | N/A | N/A |
| 8 | MOEFA | N/A | N/A | N/A |
| 9 | Public Address System. | N/A | Provided | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | basement | N/A | N/A | N/A |
| | upper floors | N/A | N/A | N/A |
| | sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | Size of riser/down-corner | N/A | N/A | N/A |
| | Number of Hydrants per floor | N/A | N/A | N/A |
| | hose Box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | | | |
| | total number of hydrants | N/A | N/A | N/A |
| | hose box | N/A | N/A | N/A |
| 13 | Pumping arrangements | | | |
| | 1. Ground level | | | |
| | a. Discharge of main Pump | N/A | N/A | N/A |
| | b. Head of main pump | N/A | N/A | N/A |
| | c. Number of main pumps | N/A | N/A | N/A |
| | d. jockey pump out put | N/A | N/A | N/A |
| | e. jockey pump head | N/A | N/A | N/A |
| | f. Standby Pump output | N/A | N/A | N/A |
| | g. Stanby Pump head | N/A | N/A | N/A |
| | h. Auto Starting/Manual stopping | N/A | N/A | N/A |
| | pump house access | N/A | N/A | N/A |
| | 2. Terrace level | | | |
| | a. Discharge of pump | N/A | N/A | N/A |
| | b. head of the pump | N/A | N/A | N/A |
| | c. Power supply | N/A | N/A | N/A |
| | d. Auto starting of pump | N/A | N/A | N/A |
| 14 | Captive water storage for fire fighting | | | |
| | 1. Underground tank capacity | N/A | N/A | N/A |
| | a. Draw-off connection | N/A | N/A | N/A |
| | b. fire service inlet | N/A | N/A | N/A |
| | c. Access to tank | N/A | N/A | N/A |
| | Over head tank Capacity | N/A | N/A | N/A |
| 15 | Exit Signage. | N/A | N/A | N/A |
| 16 | Provision of lifts. | | | |
| | a. Pressurization of lift shaft | N/A | N/A | N/A |
| | b. pressurization of lift lobby | N/A | N/A | N/A |
| | c. communication in lift car | N/A | N/A | N/A |
| | d. Fireman's grounding switch | N/A | N/A | N/A |
| | e. Lift signage | N/A | N/A | N/A |

N/17

| | | | | |
|----|---|--------------|-----|-----|
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | Not Required | | |
| | total area | | | |
| | location | | | |
| 19 | Fire control room | | | |
| | a. detector system Panel | N/A | N/A | N/A |
| | b. Flow switch Panel | N/A | N/A | N/A |
| | c. PA system Panel | N/A | N/A | N/A |
| | d. Batter backup | N/A | N/A | N/A |
| | e. Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special risks, if any: ABC Fire Extinguisher provided near electric Meter | MR | | |

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the deemed compliance of minimum standards on fire prevention and fire safety required as per DOE CIR. Dated 1.3.2011, renewal of FSC issued vide letter no.F6/DFS/MS/School/2014/SZ/1516 dated 3.12.2014 is recommended. Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
S.P. Bhardwaj
ADO (Dwarka)

~~DO/SW~~

~~Chy~~
4/12/12

882A/DOCCO
dt. 04/12/2012

~~DCFD(S2)~~

144st c/s
12/12/12

~~darf~~
5/12



~~CFD(S2)~~

m.scell
F/T 10.
7/12

FI is put up for signature please.

~~CFD(S2)~~

m.scell
12/12

S.P. Bhardwaj
11/12/12