

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/NDZ/2017 / 1797

Dated: 12/12/17

FIRE SAFETY CERTIFICATE

Certified that the M/S Multi Purpose Community Hall, at Preet Vihar Delhi, comprised of ground plus three upper floors owned/occupied by Delhi Development Authority, have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 08/11/2017 in the presence of Sh. C P Verma and found that the Assembly building is fit for occupancy class "D" with effect from .12./12./17...for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....12/12/17.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to:-

1. The Executive Engineer(Elect.),  
Electrical Division No. 1 ,Seed Bed Park,  
School Block Shakarpur,  
Delhi 110092

Extra.

**- Conditions -**

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
1. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
2. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
3. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

## INSPECTION REPORT

1. Name & address of the building : Multi Purpose Community Hall at Preet Vihar Delhi
2. Building is comprised of : Ground plus Three upper floors
3. Type of Occupancy : Assembly
4. Type of Case : NEW Case
5. Details of Previous FSC : Nil
6. Fire Safety direction letter No : F.6/DFS/MS/BP/2014/36/dated-21/01/2014
7. Date of Inspection : 08/11/17,
8. Name of the Inspecting Officers: : DO. F. Brown
9. Name of the designation of Officer  
from the building side : SH. C.P. Verma
10. Year of Construction : 2017
11. Applicant's letter No : F.23(AE(E)-2) EE (E)/ELD-1/DDA/619 dt.04/10/17&07.11.17

S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement Directive	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	12 m	24.35 m	MR
	Gate width	4.5m	6m	MR
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	02 Nos.	02 Nos.	MR
	Basement	NA.	NA	NA
	B. Width of Staircases			
	Upper Floor	02 M	02 M	MR
	Basement	NA	NA	NA
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	2 nos.	2 nos.	MR
	g. Width of Corridor	NA <i>m</i>	NA <i>m</i>	NA
	h. Door Size	<del>1.0 Mtrs.</del> <i>2M</i>	<del>1.0 M</del> <i>2M</i>	MR
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Sealed	MR
	Fire rating of shaft door	2 hrs.	2 hrs.	MR
	Water curtain	N/A	N/A	N/A
	Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	Basement	N/A	N/A	N/A
	Upper floor	NA	NA	NA
5.	Fire Extinguisher			
	Total numbers	08 Nos.	10 Nos.	MR
	types	Water type & Co2	Water type & Co2	MR
	ISI marking	ISI marked	ISI marked	MR


6	First-aid-Hose Reels.			
	Total numbers of 2 <sup>nd</sup> floors	01 nos.	01 nos.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Heat or Smoke	smoke	MR
	Location of main panel	G. floor	G. floor	MR
	Location of repeater panel	NA	NA	NA
	Alternate source of power	Battery & DG Set	Provided	MR
	Hooters	Different location	Different location	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	Basement	N/A	N/A	N/A
	Upper floor	NA	NA	NA
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants each floor	01 nos.	01 nos.	MR
	Hose box each floor	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	Total number of hydrants	02 nos.	02 nos.	MR
	Hose Box	02 nos.	02 nos.	MR
13	Pumping Arrangements.			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2280 LPM	2280 LPM	MR
	➤ Head of Main Pump	60 Mtrs	60 Mtrs	MR
	➤ Number of main pumps	2 nos.	2 nos.	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	60 mtrs	60 mtrs	MR
	➤ Standby pump out put	2280 LPM	2280 LPM	MR
	➤ Standby pump Head	60 Mtrs.	60 Mtrs.	MR
	➤ Auto Starting /Manual stopping	Required	Auto	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	60 mtrs	60 mtrs	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	50,000 Ltrs.	50,000 Ltrs.	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	5,000 Ltrs.	5,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	Required	provided	MR
	Firemen's grounding switch	Required	provided	MR
	Lift Signage	Required	provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A


The Fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of deemed compliance of the minimum standards of Fire prevention and Fire Safety measured as required under the directive issued vide letter no.F.6/DFS/MS/BP/2014/36/dated-21/01/2014

The Fire safety certificate issued under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

  
 Signature of the Inspecting Officer  
 Name : F.BROWN  
 Designation : DO

Dy. CFO (NDZ)

  
 21/11/17  
 CFO