

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2017/SZ/ 1815

Dated: 15/12/17

**FIRE SAFETY CERTIFICATE**

Certified that the **Indian Modern School** located at **Chattarpur Enclave, Phase-II, New Delhi-110074**, comprised of **Ground plus two upper floor** owned/occupied by New Parvati Educational Society was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2013/SZ/513 dated 24/04/2014. The premises was re-inspected by officer concerned of this department on 04/12/2017 in the presence of Ms. Sushma Sharama (Principal) and observed addition of third floor in the exiting building. The said school building now comprised of ground plus three upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class "**Educational Building**" Group-B, as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/12/17 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. The General Secretary, Indian Modern School, Chattarpur Enclave-II, New Delhi-110074
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	INDIAN MODERN SCHOOL, C-BLOCK, CHATTAR PUR ENCLAVE-II, NEW DELHI-74		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + Three upper floors		
4	Type of Case	Renewal + Addition of third floor		
5	Details of Previous NOC	F.6/DFS/MS/School/2014/SZ/513 Dated 24-04-2014		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	04-11-2017		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms. Sushma Sharma (Principal)		
10	Year of construction	2004, 2014		
11	Applicant letter No.	IMS/FSC/64/17-18/03 Dated 08/11/2017 (C-22)		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL / NBC requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Required	6 mtr	MR
	• Gate width	-NA-	Directly accessible	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type arrangement of exits.</b>			
	<b>a. Number of Staircase</b>			
	➤ Upper floors	One	Two	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>b. Width of Staircase</b>			
	➤ Upper floors	1.5 m	1.50 m & 0.86 m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircase to terrace</b>	Required	Two	MR
	<b>e. Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door size</b>	-NA-	-NA-	-NA-
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	• Total numbers		14 No's	MR
	• Types	ISI Marked	ABC-10, Co2-04	MR
	• ISI Marking		Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	One	MR
	• Length of hose-reel hose.	30 m	30 m	MR
	• Nozzle Diameter	5 mm	5 mm	MR


Indian Modern School, C-Block, Chattarpur Enclave-II, New Delhi



INSPECTION REPORT				
1	Name & Address of the Building	INDIAN MODERN SCHOOL, C-BLOCK, CHATTAR PUR ENCLAVE-II, NEW DELHI-74		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + Three upper floors		
4	Type of Case	Renewal + Addition of third floor		
5	Details of Previous NOC	F.6/DFS/MS/School/2014/SZ/513 Dated 24-04-2014		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	04-11-2017		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms. Sushma Sharma (Principal)		
10	Year of construction	2004, 2014		
11	Applicant letter No.	IMS/FSC/64/17-18/03 Dated 08/11/2017 (C-22)		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL / NBC requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Required	6 mtr	MR
	• Gate width	-NA-	Directly accessible	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type arrangement of exits.</b>			
	<b>a. Number of Staircase</b>			
	➤ Upper floors	One	Two	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>b. Width of Staircase</b>			
	➤ Upper floors	1.5 m	1.50 m & 0.86 m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircase to terrace</b>	Required	Two	MR
	<b>e. Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door size</b>	-NA-	-NA-	-NA-
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	• Total numbers		14 No's	MR
	• Types	ISI Marked	ABC-10, Co2-04	MR
	• ISI Marking		Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	One	MR
	• Length of hose-reel hose.	30 m	30 m	MR
	• Nozzle Diameter	5 mm	5 mm	MR

Indian Modern School, C-Block, Chattarpur Enclave-II, New Delhi

N/17

19.	<b>Fire Control Room.</b>			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-
<p>The Fire protection systems provided in the building were checked /operated and found functional at the time of inspection.</p> <p>Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/School/2014/SZ/513 dated 24.04.2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <p style="text-align: right;">   Signature of the Inspecting Officer  Name : R.N. Singh  Designation: ADO </p>				

Indian Modern School, C-Block, Chattarpur Enclave-II, New Delhi

DO (SD)

  
7/12/17

By (BCS2)  
and leave

C to (S2)

1457/CP/S2  
11/12

m.scell


FT/101

11/12

F.T letter is put up for sign. pde.

CP/S2

m.scell 11/12

  
12/12