

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No.F6/DFS/MS/School/2017/WZ/ 1823

Dated: 15/12/17

**FIRE SAFETY CERTIFICATE**

Certified that the **James Convent School** located at F-34/2 & 3 Satsang Road, Nihal Vihar Nangloi, Delhi-110041 comprised of Ground + 01 Upper Floors was issued FSC vide Letter No. **F6/DFS/MS/School/2014/WZ/334 dated 10.03.2014**. The premises was re inspected by the officers concerned of this department on **08.12.2017** in the presence of **Smt. Sangita (Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 Dated 17-01-2005 and that the premises is fit for occupancy class 'Educational' Group B with effect from 15/12/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...at New Delhi by.

15/12/17

  
(Atul Gang)  
Chief Fire Officer,  
Delhi Fire Service  
o/c  
13/12

Copy to:

The Principal,  
James Convent School located at F-34/2 & 3 Satsang Road,  
Nihal Vihar Nangloi, Delhi-110041

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building : **James Convent School** located at F-34/2 & 3 Satsang Road, Nihal Vihar Nangloi, Delhi-110041.
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2014/WZ/334 dated 10.03.2014
5. Fire Safety directives Letter No. : DOE Circular dated 17-01-2005
6. Date of inspection : 08-12-2017
7. Name of the Inspecting Officer : MukeshVerma, DO (West)
8. Name and designation of Officer  
from the building side : Smt. Sangita (Principal)
9. Year of Construction : 2001
10. Applicant's letter No. : Form 'J' Dated 29.11.2017

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.262-362 dated 17-01-2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	165 cm, 156 <del>cm</del> 142 <del>cm</del>	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5 mtr	1.5 mtr Provided	MR
	f. Door Size	1 mtr	1 mtr Provided	MR
3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR



	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	2500 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2014/WZ/334 dated 10.03.2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
Name : Mukesh Verma  
Designation : DO (West)

*Mukesh Verma 11/12/17*

*Dr. H.O. (WZ)*

*11/12/17*

*CFO - West - [Signature]*

*12/12/17*

*FT PLS*

*DGP/W*

*F.T. / F.S.C. is put up for signature please.*

*[Signature] 13/12/17*

*CFO (West) [Signature]*

*15/12/17*