

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/2017/ 62/1828

Dated: 15/12/17

FIRE SAFETY CERTIFICATE

Certified that the **Kulachi Hansraj Model School** Located at **Ground + 03 Upper Floors, Ashok Vihar Phase-III Delhi -110052** in a building comprised of Basement + Ground + 03 Upper Floors was issued FSC vide Letter No. **F6/DFS/MS/SCHOOL/2012/3696 Dated 08-10-2012**. The premises was re inspected by the officers concerned of this department on 15-11-2017 in the presence of **Mr. Ajay Arora (Ad. Officer)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance NBC and that the premises is fit for occupancy class "Educational" Group B with effect from 15/12/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...15/12/17... at New Delhi by.

(Atul Garg)
Chief Fire Officer,
Delhi Fire Service.

Copy to:

The Principal, Kulachi Hansraj Model School, Ashok Vihar Phase-III Delhi -110052

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall not be used for school activity or any other purpose.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **Kulachi Hansraj Model School, Ashok Vihar Phase-III Delhi -110052**
2. Type of Occupancy: **Educational (Basement + Ground + 3 Upper Floor)**
3. Type of Case : **Renewal**
4. Details of previous NOC **F6/DFS/MS/SCHOOL/2012/3696 Dated 08-10-2012**
5. Fire Safety directives Letter No. : ~~DOE CR-Dated-17-01-2011/~~ **BBL NBC**
6. Date of inspection : **15/11/2017**
7. Name of the Inspecting Officer : **DO/W,ADO (WP)**
8. Name and designation of Officer
from the building Side : **Mr. Ajay Arora (Adm. Officer)**
9. Year of Construction : **1985**
10. Applicant's letter No. : **Nil Dated-25/10/2017**

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE CR-Dated 17-01-2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 mtrs 4.5 mtrs Required	16m Provided Provided Provided	MR MR(Old Case) MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases <ul style="list-style-type: none"> • Upper floors • Basements 	4 nos NA	05 Provided 03 Provided	MR NA
	b. Width of staircases <ul style="list-style-type: none"> • Upper floors • Basements 	1.5mtrs. Each NA	4x152cm & 1x135cm 1x110cm, 1x138cm & 1x145cm	MR NA (Basement shall not be used)
	c. Protection of exits <ul style="list-style-type: none"> • Fire check door 	NA	Provided	NA (Basement shall not be used)
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	2 nos	02 Provided	MR
	f. Door Size	NA 1 mtr.	217 cm Provided 110 cm Provided	NA MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements Syst.			
	<ul style="list-style-type: none"> • Basements 	NA	Provided	NA (Basement

6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	4 nos	04 Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150mm	Provided	MR
	<ul style="list-style-type: none"> Number of hyd/floor 	NA	Provided at Ground Floor	NA
	<ul style="list-style-type: none"> Hose Box 	NA	Provided at Ground Floor	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> Head of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> Jockey pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> Auto Staring/Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> Discharge of pump 	900 lpm	Provided	MR
	<ul style="list-style-type: none"> Head of the pump 	40Mtrs	Provided	MR
	<ul style="list-style-type: none"> Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump 	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> Draw off connection 	NA	NA	NA
	<ul style="list-style-type: none"> Fire service inlet 	NA	NA	NA

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. **F6/DFS/MS/SCHOOL/2012/3696 Dated 08-10-2012** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Uday Vir Singh

Name Sh. Mohesh Verma

Designation ADD/CP

Designation DO/W

~~ADD/CP/W2~~ Pl. spoken
ADD/CP 23/11/17

spoken.
29/11/17

DY. CP/W2

CP/W2
11/11/17

CP/W2

6/12/17