

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**



NO.F6/DFS/MS/School/2017/SZ/ 1845

Dated: 20/12/17

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Kanya Vidhalaya, Vijay Enclave, New Delhi-110045, having three blocks namely old block comprised of ground floor only and main block & New Block comprised of ground plus one upper floor was issued fire safety certificate by this department vide letter no. F6/DFS/MS/School/2014/SZ/723 dated 13.6.2014. The said school building was re-inspected by the officer concerned of this department on 5.12.2017 in presence of Sh. Rajbir Singh (Estate manager) and found that old block ground floor building is demolished & constructed new building block having ground plus one upper floor, now school building is having three blocks comprised of ground plus one upper floor & have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi, and that the building is fit for occupancy class B "Educational building" with effect from....20/12/17... for a period of **three** years, subject to compliance of the conditions printed overleaf.

Issued on ...20/12/17..... at New Delhi by

  
( Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  


Copy to:-

1. Director (Education), GNCT of Delhi, Old Secretariat, New Delhi-110054.
2. Principal, Sarvodaya Kanya Vidhalaya, Vijay Enclave, New Delhi-110045.
3. Principal, Sarvodaya Bal Vidhalaya, Vijay Enclave, New Delhi-110045.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

**INSPECTION REPORT**

1	Name & Address of the Building	Sarvodaya Kanaya Vidhalay, Vijay Enclave, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal <b>Ground &amp; Ground plus One upper floor</b>		
4	Details of previous NOC	No.F6/DFS/MS/School/2014/SZ/723 dated 13.6.2014		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	5.12.2017		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Rajbir Singh (Estate Manager)		
9	Year of construction	Old Block 1996, 2008 New Block 2015		
10	Applicant's letter No.	SKV/VE/FS/3629 Dated 9.11.2017	<b>ground plus one upper floor(Three Blocks)</b>	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE CIR. Dated 1.3.2011/ letter dated 13.6.2014	Provided at site	Remarks MR / NMR
--------	---	---	------------------	------------------

<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	5 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A

<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos. each block Block	Provided	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.50 Mtrs. if less than 1.50 Mtrs. additional staircase of .75 Mtr. is required	Main Block: 1.21, 1.27, 1.32, 1.52 Mtr. New Blocks: 1.81, 1.60 & 1.52 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	1 No.each block	Provided	MR
	e. Width of corridor	1.50 Mtrs.	2 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr. (Double Door)	MR

<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

<b>4</b>	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	2 Nos. each block per floor CO2 OR ABC	17 Nos. Provided	MR
	Types	ISI Marked	Provided	MR
	ISI marking	ISI Marked	Provided	

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

18/10

17	Standby power supply	N/A	N/A	N/A
	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire Extinguisher provided near electric Meter			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of minimum standards on fire prevention and fire safety requirements as per DOE CIR. Dated 1.3.2011, renewal of FSC issued vide letter no.F6/DFS/MS/School/2014/SZ/723 dated 13.6.2014 is recommended.

Accordingly DFA is put up for approval and signature please.

*Sanyal*  
6/12/17

S.P. Bhardwaj  
ADO (Dwarka)

*AD/SW*

*[Signature]*  
7/12/17

881/DO/SW  
6/12/2017

*DCFB(S2)*

1464/CFB2  
15/12/2017

*[Signature]*  
11/12



*CFB(S2)*

*m-sell*

*[Signature]*  
13/12

*FT is put up for signature please*

*Sanyal*  
18/12/17

*CFB(S2)*

*m-sell* 20/12/17