

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No. F.6/DFS/MS/EH/2017/SZ / 27

Dated: 02.01.18

FIRE SAFETY CERTIFICATE

Certified that the M/s Spinn's Restaurant, G-2A & G-2B, Ground Floor Only, Sonia PVR Complex, Vikas Puri, New Delhi-110018 is running at ground floor of the Sonia PVR Complex building was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2014/SZ/1083 dated 28.08.2014 owned/ occupied by M/s Spinn's Restaurant. The building was re-inspected by the officers concerned of this department on 11.12.2017 in the presence of Sh. Ramesh (Sr.Manager) and found that M/s Spinn's Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (at ground floor only) is fit for occupancy class Group "D" Assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on..... 02/01/18 at New Delhi.


(VIPIN KENTAL)
CHIEF FIRE OFFICER
AC sam
28/12/17

Copy to:-

1. D.H.O, West Zone, S.D.M.C,
Public Health Department, Vishal Enclave,
Rajouri Garden, New Delhi-110027
(Ref. No. D-2031/HD/WZ dated 16.06.2016)
2. The Manager,
M/s Spinn's Restaurant, G-2A & G-2B,
Ground Floor Only, Sonia PVR Complex,
Vikas Puri, New Delhi-110018.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/s Spinns Restaurant, G-2A & G-2B, Ground Floor Only, Sonia PVR Complex, Vikas Puri, New Delhi-110018.
2. Type of Occupancy : Group D (Assembly Building)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/EH/2014/SZ/1083 dated 28.08.2014
5. Fire Safety directives letter No : N/A
6. Date of inspection : 11.12.2017
7. Name of Inspecting Officers : D.O M.K. Chattopadhyay & A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Ramesh (Sr.Manager)
9. Year of Construction : 2011
10. Applicant's letter No. : Nil dated 18.11.2017

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 28.08.2014	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible (09 mtrs) 4.5 mtrs 06 mtrs	09 mtrs Directly accessible from internal road Provided	MR MR MR
2.	Number, Width, Type & Arrangement of Exits			
				(Restaurant is at GF only)
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	N/A	N/A	N/A
		N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	N/A	N/A	N/A
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
		N/A	N/A	N/A
	e. Width of Corridor			
		N/A	Opening in hall	N/A
	f. Door Size	02 mtrs	200, 125 & 125 cms (including frames)	MR being old case
3.	Compartmentation			(Restaurant is at GF only)
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
				(Restaurant is at GF only)
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 No.'s ABC/CO ₂	Provided	MR
			Provided	MR
		ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
				(Restaurant is at GF only)
	<ul style="list-style-type: none"> • Total numbers on ground floor • Length of hose reel hose • Nozzle diameter 	One 30 mtrs	Provided	MR
			Provided	MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System (Restaurant is at GF only)			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
11.	Internal Hydrants (Restaurant is at GF only)			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box 	100 mm	Provided	MR
		01 No.	Provided	MR
		01 No.	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements (common with Sonia PVR Complex)			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 			
		2280 LPM	Provided	MR
		70 mtrs	Provided	MR
		One	Provided	MR
		220 LPM	Provided	MR
		70 mtrs	Provided	MR
		2280 LPM	Provided	MR
		70 mtrs	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting (common with Sonia PVR Complex)			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	130000	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10000	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. (Restaurant is at GF only)			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area 	N/A	N/A	N/A

18/14

19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued vide letter number F6/DFS/MS/EH/2017/SZ/2199 dated 24.08.2017 has been complied. ✓

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/EH/2014/SZ/1083 dated 28.08.2014, renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

[Signature]
18/12/17

Signature of Inspecting Officer
Name:- M.K. Chattopadhyay
Designation:- Divisional Officer

[Signature]
14/12/17

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

910/Docsw
dt. 29/12/17

1479/cfo 52
22/12-21/18
Dy. C.F.O. (South Zone)



CFO (SZ)

[Signature]
19/12

M-scull *[Signature]*
22/12

FT letter is put up for signature please

CFO (SZ)

M-scull *[Signature]*
27/1/18

[Signature]
28/12/17