

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/School/2017/ *ND2/37*

Dated: *03/01/18*

**FIRE SAFETY CERTIFICATE**

Certified that the Government Girls Sr. Sec. School No. 02 located at Tukmirpur, Delhi-110094, comprised of ground plus three upper floors (New Building only), owned/occupied by Government Girls Sec. School was inspected by the officer concerned of this department on 22/12/17 in the presence of Mr. Anoop Pandey, Site Engineer and found that the school building have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from ....*03/01/18* for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

**This Fire Safety Certificate does not cover the old building blocks.**

Issued on.....*03/01/18*.....at New Delhi by

*VK*  
*29/12*  
**(Vipin Kental)**  
**Chief Fire Officer**

To,

The Assistant Engineer (E)  
PWD Edu. M1 Sub Div. IV,  
ITI Campus Pusa  
New Delhi 110012

*o/c*  
*he*

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Govt Girls Sr. Sec. School, No 2  
Tukmirpur, Delhi-110094
1. Building is comprised of : G+ 3 Two Separate Blocks (New Building)
2. Type of Occupancy : Educational
3. Type of Case : New
2. Details of Previous NOC letter : Nil
4. Fire Safety directive letter No. : NBC part IV
5. Date of Inspection : 22/12/2017
6. Name of the Inspecting officers : ADO V. B. Yadav
7. Name and designation of Officer  
from the building side : Mr. Anoop Pandey (Site Engineer)
8. Year of Construction : 2017
9. Applicant's letter No : Letter No.AE-IV/2017-18/84 dated 20/11/2017

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	06 mtr.	MR
	• Gate width	4.50 mtr	4.50 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 nos. 01 in each block	02 nos. 01 in each block	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	1.50 mtr	1.82 mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 nos. in each block	01 nos. in each block	MA
	e. Width of Corridor	1.50 mtr. in each block	1.80 mtr. in each block	MR
	f. Door Size	01 mtr.	1.12 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	19 nos.	20 nos	MR
	• Types	ABC /CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• IS marking	ISI marked	Provided	MR

\* The school was initially in the name of GGS S. Tukmirpur. Now bifurcated to No 1 & No 2. The old file is with GGS S. No 2, Tukmirpur, Delhi.

06	First-Aid-Hose Reels			
	Total numbers on each floor	02 nos. (01 in each block)	02 nos (01 in each block)	MR
	• Length of hose reel hose	30 mtr	30 mtrs	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump in each Block	450 LPM	450 LPM X 2	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 ltr each.	20,000 ltr	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply		N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:		N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under NBC Part IV, it is recommended to issue Fire Safety Certificate.

*[Handwritten Signature]*  
26/12/17

Signature of the Inspecting Officer  
Name :- Vijay Bahadur  
Designation :- A.D.O (T.Pur)

DO(ED)  
*[Handwritten Signature]*  
26/12/17

DYCP/MDN  
*[Handwritten Signature]*

- CF  $\phi$  - m-scell F 7 101.  
*[Handwritten Signature]*  
27/12

333/cf 1102  
29/12

As approved FT FSE is put up for signature please.

CPO (NDZ)  
m-scell *[Handwritten Signature]*  
29/12

*[Handwritten Signature]*  
28/12/17