

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/NDZ/2018/BNOT/56

Dated: 08/01/18

FIRE SAFETY CERTIFICATE

Certified that the M/S Royal Banquet Hall at 162/22, Jheel Khuranja, Geeta Colony, Delhi, comprised of ground plus one upper floor owned/occupied by Royal Banquet Hall, have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 21/12/2017 in the presence of Sh. Dheeraj Bindra and found that the **Assembly building** is fit for occupancy class "D" 'Assembly (Banquet Hall)' with effect from ..08/01/18....for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....08/01/18.....at New Delhi by

5/1/18
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

5/1/18

Copy to:-

1. The Dy. Health Officer,
East Delhi Municipal Corporation, Health Department,
Shahdara (South) Zone, Karkardooma, Shahdara, Delhi.

2. Sh. Dheeraj Bindra,
Royal Banquet Hall,
162/22, Jheel Khuranja,
Geeta Colony, Delhi.

INSPECTION REPORT

1. Name & address of the building : Royal Banquet Hall at 162/22, Jheel Khuranja, Delhi.
2. Building is comprised of : Ground plus one upper floor
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/BNQT/2014/NDZ/1377 Dated 07/11/14.
6. Fire Safety direction letter No : NBC Part IV
7. Date of Inspection : 21/12/17
8. Name of the Inspecting Officers : DO. F. Brown
9. Name of the designation of Officer
from the building side : Sh.Dheeraj Bindra
10. Year of Construction : 1991
11. Applicant's letter No : Nil Dated 27/11/2017

S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement Directive	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	30 m	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	02 Nos.	02 Nos.	MR
	Basement	N/A	N/A	N/A
	B. Width of Staircases			
	Upper Floor	1.5 m	1.5 m	MR
	Basement	N/A	N/A	N/A
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	2 nos.	2 nos.	MR
g. Width of Corridor	N/A	N/A	N/A	
h. Door Size	2.0 m	2.0 m	MR	
3	Compartmentation.			
	Fire check door	N/A	N/A	N/A
	Sealing of electrical shafts	N/A	N/A	N/A
	Fire rating of shaft door	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	Basement	N/A	N/A	N/A
	Upper floor	Required	Ventilated	N/A MR
5.	Fire Extinguisher			
	Total numbers	06 no.	08 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floors	1 nos.	1 nos.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of main panel	N/A	N/A	N/A
	Location of repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooters	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	Basement	N/A	N/A	N/A
	Upper floor	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants each floor	01 nos.	01 nos.	MR
	Hose box each floor	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access			
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	N/A	N/A	N/A
	Access to tank	N/A	N/A	N/A
	Overhead Tank capacity	10,000 ltrs.	10,000 ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A

The Fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping In view of deemed compliance of the minimum standards of Fire prevention and Fire Safety measured as required under the rules. The Fire Safety Certificate issued vide latter no. F6/DFS/MS/BNQT/2014/NDZ/1377 Dated 07/11/14.

The Fire safety certificate renewed under rule 37, of the Delhi Fire Service Rules 2010 is recommended.

[Handwritten Signature]
27/12/17

Signature of the Inspecting Officer
Name : F. BROWN
Designation : DO

338/CFO NDZ
2/1/18/5/11

Dy. CFO (NDZ) *[Handwritten Signature]*
10/2/18
C.F.O. m-scott
11/1/18