

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No.F.6/DFS/MS/School/2017/NDZ/ 59

Dated: 08/01/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Nav Bharat Adarsh Public School, F-246, Khajuri Khas, Wazirabad Road, Delhi-110094 comprised of Ground plus three upper floors owned / occupied by Nav Bharat Adarsh Public School was issued FSC vide letter No. F.6/DFS/MS/School/2014/NDZ/900 Dated 22/07/14. The school building was re-inspected by the officer concerned of this department on 28/12/17 in presence of Puneet Kumar, Principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 08/01/18 at New Delhi by

ve
8/1/18

(vipin Kental)
Chief Fire Officer
Delhi Fire Service

ok

To,
The Principal,
Nav Bharat Adarsh Public School,
F-246 Khajuri Khas, Wazirabad Road, Delhi-94.

Copy to:-
The Dy. Director of Education
D-Block, Yamuna Vihar, Delhi-53.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
1. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
2. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
3. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
5. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : Nav Bharat Adarsh Public School, F-246, Khajuri Khas, Wazirabad Road, Delhi-94.
2. Building is comprised of : G+3 upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/School/2014/NDZ/900 Dated 22/07/14
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 28/12/17
8. Name of the Inspecting officers : ADO Om Prakash
9. Name and designation of Officer from the building side : Puneet Kumar (Principal)
10. Year of Construction : G floor-1994, 1st, 2nd & 3rd floor-2000.
11. Applicant's letter No : N.B.A.P.S/2017/DEC/09 Dated. - 09/12/17

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remark MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 Mtrs N/A N/A	06 Mtrs N/A N/A	MR N/A N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	01 no. N/A	02 no. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 m N/A	1.6 m & 1.0 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	e. No. of continuous staircases to terrace	01 no.	02 no.	MR
	g. Width of Corridor	1.5 m	1.5 m	MR
	h. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A N/A	N/A N/A	N/A N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • types 	09 nos. ABC & Co2	10 nos. ABC & Co2	MR MR
	<ul style="list-style-type: none"> • ISI marking 	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 lpm	450 lpm	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltrs.	10,000 ltrs.	MR
15	Exit Signage.	Required	Provided	MR

IRN17

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules.

The Fire safety Certificate issued vide letter no. F.6/DFS/MS/School/2014/NDZ/900 Dated 22/07/14 has renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Om Parkash 28/12/17

Signature of the Inspecting Officer
Name: Om parkash
Designation: ADO Shahdara

DO/ED submitted for approval plan.

[Signature]
28/12/17

339/cfo/NDZ
17/11/18 18/11/18

DCFO/NDZ *[Signature]*

G.F.C. - miscell *[Signature]* 17/11/18

F.t. bellu is prepared and put up for signatory plan.

cfo (HQ)

miscell *[Signature]*

Om Parkash
5/1/2018