

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2018 / School / 67

Dated: 09 / 01 / 2018

FIRE SAFETY CERTIFICATE

Certified that the **Little Fairy Public School** located at **Hudson line Kingsway Camp, Delhi-110009** comprised of **Ground and 03 upper floors** owned/ occupied by **Little Fairy Public School** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/School/2013/216** dated **26.04.2013** The premise was re-inspected by the officer concerned of this department on **18.12.2017** in the presence of **Mr.R.S Khurana /Chairman** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from**09/01/18**... for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on**09/01/18**..... at New Delhi


(Atul Garg)
Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Little Fairy Public School, Hudson line Kingsway Camp, Delhi-110009.

INSPECTION REPORT

1. Name & address of the building : Little Fairy Public School, Hudson line Kingsway Camp, Delhi-110009.
2. Type of Occupancy : Educational
3. Type of Case : Renewal - G+03 Upper floor
4. Details of previous NOC : F-6/DFS/MS/School/2013/216 dated 26.04.2013
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 18/12/2017
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : R.S Khurana /Chairman
9. Year of Construction : 1997/2000
10. Applicant's letter No. : Nil dated 18.09.2017

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education letter dated 17.01.2005	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6 m	MR
	• Gate width	4.5m	4.77 m	MR
	• Width of internal road	NA	5 m	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50 m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	02	2	MR
	d. No. of continuous staircases to terrace	1.50m	2m	MR
	e. Width of Corridor	1 m	1.15 m	MR
	f. Door Size			
	3	Compartmentation.		
• Fire check door		NA	NA	NA
• Sealing of electrical shafts		NA	NA	NA


	<ul style="list-style-type: none"> • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	12 nos	14 nos	MR
		ABC/Co2	ABC-12 / Co2- 2	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	02	02 each floor	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100mm	100mm	MR
		02	02	MR
		02	02	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50,000ltr	50,000ltr.	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 ltrs	10,000ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Location 	N/A	N/A	N/A
19	Fire Control Room			

	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular / NBC Part 4, the FSC issued vide letter of even no 216 dated 26.04.2013 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended



Signature of the Inspecting Officer
 Name :- Rajesh Kumar
 Designation:- ADO/RN

~~Dy Cfo/w2~~
~~Cfo - West~~
~~11/11/17~~
 28/10/17
 K.P.M.S

~~ADO/RN~~

As approved, F.T. letter is
 tautup for your signature pl

~~Cfo/w2~~
~~11/11/17~~

1/11/17

14/5/17