

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SCHOOL/2018/ 60

Dated: 09/01/18

**FIRE SAFETY CERTIFICATE**

Certified that Govt. Sarvodaya Co-Ed. Vidyalaya (ID-1413003) located at Ghewra, New Delhi-110081, comprised of (Two Blocks) Ground floor only owned / occupied by Govt. Sarvodaya Co-Ed. Vidyalaya, has already been issued NOC / FSC by this department vide letter No. F6/DFS/MS/2015/School/117 dated 23.01.2015. The premises was re-inspected by the officer concerned of this department on 23.12.2017 in the presence of Sh. Sanjeev Kumar (Vice Principal) and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Director of Education, GNCT of Delhi vide letter dated 01.03.2011 and that the building / premises is fit for occupancy class Educational (Group B) with effect from ....09/01/18....for a period of 3 (three) years subject to conditions printed below.

**Issued on** 09/01/18 **at New Delhi by.**

(ATUL GARG)  
CHIEF FIRE OFFICER.

**Copy to :-**

1. Vice Principal, Certified that Govt. Sarvodaya Co-Ed. Vidyalaya (ID-1413003) Ghewra, New Delhi-110081.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

1. Name & address of the building: **Govt. Servodaya Co-Ed. Vidyalaya (ID-1413003) Ghewra, New Delhi-110081.**
2. Type of Occupancy : **Educational (Ground Floor only) (Two Blocks)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/2015/School/117 dated 23/01/2015**
5. Fire Safety directives Letter No. : **DOE Circular dated 01.03.2011**
6. Date of inspection : **23/12/2017**
7. Name of the Inspecting Officer : **A. K. Jaiswal**
8. Name and designation of Officer  
from the building side : **Sh. Sanjeev Kumar (Vice Principal)**
9. Year of Construction : **1986**
10. Applicant's letter No. : **Nil**

Plot Area-979 m2, Covered Area-1740.24 m2
--

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circ. Dated 01/3/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.0 mtr. (Double Door)	1.05 mtr x 1 1.10 mtr x 1	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	18	26	MR
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	M/R
	• IS marking	Required	Provided	M/R

6.	First – Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A

15	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-A) General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route ..... Clear.....
2. LPG cylinders in laboratories ..... Nil.....
3. Electric wiring ... Conduit Wiring ..... MCB and ELCB .....  
Electric circuit .....
4. Electric meter board ..... Not under the staircase.....
5. Basement use as per BBL 1983 ..... NA.....
6. Emergency telephone no. board ..... Displayed.....
7. Generator set ..... Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/2015/School/117 dated 23/01/2015** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O. (w)

*Mukherjee*  
3/1/18

*Dy. ADO (W2)*

*cto wad*  
8/1/18

*[Signature]*  
4/1/18

FF PL

*Ak Jaiswal*  
26/12/17

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (Jwala Puri)