

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/2018/ 155

Dated: 23/01/2018

FIRE SAFETY CERTIFICATE

Certified that the **Vijay Public School**, Located at, **51-A, Ground Floor, Inderlok, Delhi – 110035** in a building comprised of **Ground+ 2Upper floor** was issued FSC vide Letter No. F6/DFS/MS/School/2015/WZ/98 Dated-20/01/2015. The premises was re inspected by the officer concerned of this department on 08-01-2018 in the presence of Ms. Indira Rawat (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance Circular DOE 3298-3398 dated 01-03-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 23/01/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/01/18 at New Delhi by.

(Atul Garg)

Chief Fire Officer
Delhi Fire Service

Copy to: - The Principal, Vijay Public School, 51-A, Ground Floor, Inderlok, Delhi – 110035

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. All the exit route shall be kept free from any obstruction.
7. The 1st & 2nd Floors shall be not used strictly for school activities or other hazardous activities.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **Vijay Public School**, Located at, **51-A, Ground Floor, Inderlok, Delhi- 110035.**
2. Type of Occupancy : Educational (School running at ground floor in a building comprising Ground + 2 Upper Floor, 1st & 2nd Floor are being used for storage of old furniture, household etc)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2015/WZ/98 Dated- 20/01/2015
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 08-01-2018
7. Name of the Inspecting Officer : Udai vir singh, ADO (WP)
8. Name and designation of Officer
from the building side : Ms. Indira Rawat (Principal)
9. Year of Construction : 1990
10. Applicant's letter No. : Form j dated- 07/12/2017

No. of Students=103
No. of class rooms=04
Plot area=180 m ²
Covered area=180m ²

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	6 m Provided	MR
	• Gate width	Accessible	Provided on road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	1mtr (Including door frame)	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2015/WZ/98 Dated-20/01/2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~No 15/1/18~~
Signature of the Inspecting Officer

Name Uday Ver Singh

Designation ADO/UP

Signature of the Inspecting Officer

Name

Designation

~~D/O~~
~~16/1/18~~

~~Dy CTO (WZ)~~
~~19/1/18~~
FT Plc

~~18/1/18~~