

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/School/2018/SZ/ 152

Dated: 23/1/18

FIRE SAFETY CERTIFICATE

Certified that the **Tagore Shiksha Niketan** located at **D-91, Meethapur Extension, Badarpur, New Delhi-110044**, comprised of **ground plus one upper floor** was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2015/SZ/729 dated 12/05/2015. The premises was re-inspected by officer concerned of this department on 04.01.2018 in the presence of Mr. Hemant Kaushik (Manager) of the school and observed addition of second floor in existing building. The school building comprised of ground plus two upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **“Educational Building, Group-B”** as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/1/18 at New Delhi by

23/1
(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Manager, Tagore Shiksha Niketan, D-91, Meethapur Extn., Badarpur, New Delhi-44
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.”

INSPECTION REPORT

1	Name & Address of the Building	TAGORE SHIKSHA NIKETAN, D-91, MEETHAPUR EXTN, BADARPUR, NEW DELHI- 44 (ID-1925363)		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + 02 upper floors		
4	Type of Case	Addition / Alteration		
5	Details of Previous NOC	F.6/DFS/MS/School/2015/SZ/729 dated. 12-05-2015 (for ground plus one upper floor)		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	04-01-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Hemant Kaushik (Manager)		
10	Year of construction	2007, 2014 & 2016		
11	Applicant letter No.	TSN/F/12/09 Dated 20/12/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	6 mtr	MR
	• Gate width	-NA-	3.5m & 1.70m	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits			
	a) Number of Staircase			
	➤ Upper floors	One	Two	MR
	➤ Basement floor	NA	NA	NA
	b) Width of Staircase			
	➤ Upper floors	1.50m	1.50 m & 1.25 m	MR
	➤ Basement floor	NA	NA	NA
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	One	One	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1.0 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	09 No's	09 No's	MR
	• Types	ABC/Co2	ABC-09	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR
	• Nozzle Diameter	05 mm	Provided	MR

7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement.	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	b) Terrace Level			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	10,000 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

N/

19. Fire Control Room.			
• Detector System Panel.	N/A	N/A	N/A
• Flow Switch Panel.	N/A	N/A	N/A
• PA system Panel.	N/A	N/A	N/A
• Battery backup	N/A	N/A	N/A
• Building floor plan	N/A	N/A	N/A
20. Special Fire Protection System for the Protection of special risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the building were checked / operated at random and found functional at the time of inspection. Shortcoming communicated vide letter dated 15/12/2017 (C-34) found complied.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.

fuwz
09/11/18

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO (BCP)

Tagore Shiksha Niketan, D-91, Meethapur Extn, Badarpur, New Delhi-44

DO (SD)

Anilash
11/11/18

dy. CPO (S2)

Agarwal

1544/CF/S2
17/1/23/11



CFO S2 M.Scell FT M. *W*
17/11

F.T letter is put up for signature.

CFO/S2 M.Scell *W*
29/11

fuwz
19/11