

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/GH/2018/SZ/ 135

Dated: 22/01/18

FIRE SAFETY CERTIFICATE

Certified that Guest House in the name and style of M/s **Hotel Aero Indus** located at RZA-54-C, Road No-1, A-Block, Mahipalpur Extension, New Delhi-110037, comprised of Ground floor (Reception), 1<sup>st</sup> floor (04 G/Room) 2<sup>nd</sup> floor (04 G/room) 3<sup>rd</sup> floor (04 G/Room), 4<sup>th</sup> floor (04 G/Room) total 16 guest rooms was inspected by officer concerned of this department on 06/01/2018 in presence of Mr. R.P. Chauhan (Manager) of the guest house and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Residential Building, Group-A**" as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/01/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. The Additional C.P. (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049
2. The DHO, South MCD, Public Health Deptt, Najafgarh Zone, New Delhi-110043
3. M/s Hotel Aero Indus, RZA-54-C, Road No-1, Block-A, Mahipalpur Extn, New Delhi-37

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."




INSPECTION REPORT				
1	Name & Address of the Building	HOTEL AERO INDUS, RZA-54-C, ROAD NO-1, A-BLOCK, MAHIPALPUR EXTN, NEW DELHI-110037		
2	Type of Occupancy	Residential & Lodging, Group-A (Guest House)		
3	Building Comprised of	Ground + 04 upper floors		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	06-01-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. R.P. Chauhan (Manager)		
10	Year of construction	2009	Ground floor (Reception), 1 <sup>st</sup> floor (04 G/Room), 2 <sup>nd</sup> floor (04 G/Room), 3 <sup>rd</sup> floor (04 G/Room), 4 <sup>th</sup> floor (04 G/Room) <b>Total- 16 Guest Rooms</b>	
11	Applicant letter No.	Nil dated Nil, ODD No. 16839 dated 22/12/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	6 mtr	Provided	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type and arrangements of exits.</b>			
	<b>a) Number of Staircase</b>			
	• Upper floors	One	One	MR
	• Basement floor	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	• Upper floors	1.25m	1.25m	MR
	• Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	One	One	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1m	1.10m (final exit)	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	10 Nos	10 Nos.	MR
	• Types	ABC / Co2	ABC type	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	05 mm	Provided	MR

Hotel Aero Indus, RZA-54-C, Road No-1, A-Block, Mahipalpur Extn, New Delhi




<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	-NA-	-NA-	-NA-
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
<b>11.</b>	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
<b>12.</b>	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
<b>13.</b>	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40 Mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
<b>14.</b>	<b>Captive water storage for fire fighting.</b>			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	5,000 Ltr.	Provided	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
<b>17</b>	<b>Standby Power Supply</b>	Required	Provided	MR
<b>18.</b>	<b>Refuge Area</b>			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-


Hotel Aero Indus, RZA-54-C, Road No-1, A-Block, Mahipalpur Extn, New Delhi

19.	<b>Fire Control Room.</b>	-NA-	-NA-	-NA-
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-
<p>The Fire protection systems provided in the building were checked/ operated at random and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <p style="text-align: right;">               Signature of the Inspecting Officer              Name : R.N. Singh              Designation: ADO (BCP)         </p>				

Hotel Aero Indus, RZA-54-C, Road No-1, A-Block, Mahipalpur Extn, New Delhi


DO (SD)

  
11/1/18



1539/CF 52  
171/22-1




  
11/1

FT 10/1

CFD (S/)

M. S. SELL

  
16/1

FT letter is put up for signature of   
19/1

CFD/S/

M. S. SELL

  
21/1