

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/2018/ ND2/116

Dated : 18/01/18

FIRE SAFETY CERTIFICATE

Certified that the **Gulab Bhawan** located at **6, Bahadur Shah Zafar Marg, New Delhi** comprised of **Basement + Ground + 04 Upper floors** owned/occupied by Gulab Bhawan was issued FSC by this department vide letter No.F6/DFS/MS/2005/HR/2506/Con./HV/460 dated **22/08/2005**. The premises was re-inspected by the officer concerned of this department on **27/12/17** in the presence of **Sh. Rajinish (Project Head)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Business Building** with effect from 18/01/18 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 18/01/18 at New Delhi by.

18/1
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

Authorised Signatory,
M. Gulan Singh & Sons Pvt. Ltd.,
Gulab Bhawan, 6, B.S.Z. Marg,
New Delhi – 110002.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Gulab Bhawan, 6, Bahadur Shah Zafar Marg, New Delhi – 110002.
2. Type of occupancy : Business Building B + G + 04 upper floor
3. Type of case:- : Renewal
4. Details of previous NOC : F6/DFS/MS/2005/HR/2506/Con./HV/460 dated 22/08/2005
12 point based
5. Fire safety directives No. : N/A
6. Date of inspection:- 17/12/17
7. Name of the inspecting officer : Sh. M.K. Sharma ADO/CC
8. Name & designation of officer
From the building side : Sh. Rajnish (Project Head)
9. Year of construction : 1957
10. Applicant's letter No : Nil Dated 07/12/2017

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	6.5 Mtr.	MR
	2) Gate width	06 mtr.	06 mtr.	MR
	3) Width of internal road	05 mtr.	05 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03 Nos.	03 Nos.	MR
	2. Basements	02 Nos.	02 Nos.	MR
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1.5 mtr. each	MR
	2. Basements	1.5 mtr.	1.50 mtr. each	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	03	03	MR
	E. Width of corridor	NA	NA	NA
	F. Door size	01 mtr.	01 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	NA	NA	NA
	5) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	1) Basements	30 ACPH	Exhaust fan	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	215 Nos.	220 Nos.	MR
	2) Types	ABC, CO2	ABC, CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number	02	02	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR

M

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	Floor wise	Floor wise	MR
	4) Alternate source of power	D.G set	D.G set	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	NA	NA	NA
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 MM	150 MM	MR
	2) Number of hydrants per Basement	03	03	MR
	3) Hose box each floor	03	03	MR
12.	Yard Hydrants			
	1) Total number of hydrants	04	04	MR
	2) Hose box	04	04	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	1200 LPM	1200 LPM	MR
	b) Head of main pump	100 mtr.	100 mtr.	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM	MR
	b) Head of pump	35 mtr.	35 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00,000 ltr.	1,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	50,000 liter.	50,000 liter.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR

17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	NA	NA	NA
	Total area location	NA	NA	NA
19.	Fire Control Room	Required	Provided	MR
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/2017/1851 dated 24/07/2017 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/2005/HR/2506/Con./HV/460 dated 22/08/2005 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

M.K. Sharma

Name :- M.K. Sharma
Designation :- ADO (CC)

~~Done~~ *13/11/18*
By *CFO (NDZ)*

494/CFO/NDZ
17/11/18/1

C.F.P. *M.Scell* *FTM*
16/11

F.T. letter is put up for sign. jst

CFO (NDZ)

M.Scell *18/11*

M.K. Sharma
18/11/18