

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.

F6/DFS/MS/EH/2018/154

Dated:

23/01/18

FIRE SAFETY CERTIFICATE

Certified that the Green Lounge Banquet Located at LGF-1 &LGF-2(Basement) of Aggarwal Citi Mall Plot No-05, Road No-44, Pitampura, New Delhi-110034 in a building comprised of Basement + Ground + 3Upper Floors owned/occupied by Green Lounge Banquet was issued FSC vide Letter No.F6/DFS/MS/EH/2014/479 Dated-16/04/14, The premises was re inspected by the officers concerned of this department on 13-09-2017 in the presence of **Sh. Rajeev Nagpal (Director)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 23/01/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/01/18..... at New Delhi by.

(Atul Garg)

Chief Fire Officer,
Delhi Fire Service.

Copy to:

Green Lounge, Banquet Ground floor of LGF-1 &LGF-2, Aggarwal Citi Mall Plot No-05, Road No-44, Pitampura, New Delhi-110034 .

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expir

1. Name & address of the building: Green Lounge Restaurant Located at LGF-1 & LGF-2(Basement) of 39-43, Aggarwal Citi Mall Plot No-05, Road No-44, Pitampura, New Delhi-110034.
2. Type of Occupancy : Class-D Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2014/479 Dated-16/04/14
5. Fire Safety directives Letter No. : F-6/DFS/MS/2005/1527 Dated 19/07/2005 For the mall
6. Date of inspection : 13-09-2017
7. Name of the Inspecting Officer : DO/w & ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Rajeev Nagpal(Director)
9. Year of Construction : 2014
10. Applicant's letter No. : Nil Dated 28/09/2017

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	16 m 6 m As per sanction plan	24 m Provided Provided Provided	MR MR MR
2.	Number, width, Type & Arrangements of exits			
	g. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA	NA	NA
		2 & Ramp	2 Provided	MR (Old Case)
	h. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA	NA	NA
		Old case	One varies from 1.5m to 2 m 1x0.9m & 1x0.83m & Ramp 5mtrs	MR(Old case)
	i. Protection of exits	All the Exit lead to Ground level in open		
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
		NA	NA	NA
	j. No of continuous staircase to terrace	NA	NA	NA
	k. Width Of Corridor	NA	NA	NA
	l. Door Size	Old case	110cm,95cm & 2x120cm	MR (Old case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floor 	Required	Provided	MR
		NA	NA	NA

5.	Fire Extinguishers			
	• Total numbers	04 nos.	04 Provided	MR
	• Types	ABC & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	2 Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	At strategic location	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants Common with Mall			
	• Size of riser/down- comer	150 mm	Provided	MR
		2	2	MR
	• Number of hydrants per floor	2	2	MR
	• Hose Box			
12.	Yard Hydrants Common with Mall			
	• Total number of hydrants	4	4	MR
	• Hose Box	4	4	MR
13.	Pumping Arrangements Common with Mall			
	• Ground Level	NA	2280 lpm	NA
	• Discharge of main pump	NA	60m	NA
	➤ Head of main pump	NA	1	NA
	➤ Number of main pumps	NA	180lpm	NA
	➤ Jockey pump out put	NA	60 m	NA
	➤ Jockey pump head	NA	2280lpm	NA
	➤ Standby Pump out put	NA	60m	NA
	➤ Standby Pump Head	NA	Provided	NA
	➤ Auto Staring/Manual stopping	NA	Provided	NA
	➤ Pump House Access			
	• Terrace level	900 lpm	Pumping arrangement at Ground level is at higher side	MR
	➤ Discharge of pump	60 m	Not Provided	MR
	➤ Head of the pump	Required	DO	MR
	➤ Power supply	Required	DO	MR
	➤ Auto starting of pump			
14.	Captive water Storage for fire fighting Common with Mall			
	• Under ground tank capacity	NA	200000ltrs	NA
		NA	Provided	NA
	➤ Draw of connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	10,000 ltrs	Provided	MR
	• Overhead Tank capacity			
15	Exit Signage	Required in the restaurant	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Pressurization in lift Car	NA	NA	NA

17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2014/479 Dated-16/04/14 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note :- The Banquet have separate entry/ Exit and segregated from the mall however the firefighting system is common with mall and found functional at the time of inspection. The NOC for the Mall is due for renewal.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name **Udai Vir Singh**

Name **Sh Mukesh Verma**

Designation **ADO (WP)**

Designation **DO (West)**

NOC for mall is due for renewal.

ADO/WP

Mukesh 28/9

ADO/WP

May kindly see note "A" the banquet have separate entry/exit.

May be considered submitted plz

Mukesh 29/9

Mukesh 28/9/18