

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/2018/ 137

Dated: 23/01/2018

FIRE SAFETY CERTIFICATE

Certified that the **M/s Chilis Grill & Bar (A unit of premier Restaurant Pvt.ltd)** located at **Shop No. 8 & 9, 2nd Floor, Pacific Mall, Tagore Garden, New Delhi** was issued FSC vide Letter No. F6/DFS/MS/EH/2014/809 dated 30-06-2014 to **Spaghetti Kitchen**. The FSC to the Pacific Mall has already been issued vide letter no. F-6/DFS/MS/2017/WZ/577 dated 21/04/2017. The premises was re inspected by the officers concerned of this department on 06-12-2017 in the presence of Mr. Neeraj (Restaurant Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 23/01/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/01/18 at New Delhi by.


(Atul Garg)

Chief Fire Officer,
Delhi Fire Service

Copy to : 1) DY Health Officer, West Zone, SDMC, Rajori Garden, New Delhi

2) M/s Chilis Grill & Bar (A unit of premier Restaurant Pvt.ltd), Premises No. 8 & 9, 2nd Floor, Pacific Mall, Tagore Garden, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **M/s Chilis Grill & Bar (A unit of premier Restaurant Pvt.ltd)** located at Shop No. 8 & 9, 2nd Floor, Pacific Mall, Tagore Garden, New Delhi
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Situating in Mall already issued NOC vide letter no. F6/DFS/MS/2017/WZ/577 dated 21-04-2017)
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2014/WZ/809 dated 30-06-2014(Issued to Spaghetti Kitchen)
5. Fire Safety directives Letter No. : FSC Issued to the mall
6. Date of inspection : 06-12-2017
7. Name of the Inspecting Officer : Dy CFO/Wz, DO/W & ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Neeraj (Restaurant Manager)
9. Year of Construction : 2011
10. Applicant's letter No. :D-2832/HQ/WZ Dated-13/11/2017

No of seats= 98 Covered Area of rest =248 m²
--

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 m	30m Provided	MR
		NA	NA	NA
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 & 1m	1.5m Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Required	145cm,86cm	MR(Old Case)

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	02 nos. each type DCP & CO ₂ ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Required	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system (Common with mall)			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Smoke	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants: Common with the mall			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	150 mm	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA

13.	Pumping Arrangements: Common with the mall			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump 	NA	Common with the mall	NA
	➤ Head of main pump	NA	Common with the mall	NA
	➤ Number of main pumps	NA	Common with the mall	NA
	➤ Jockey pump out put	NA	Common with the mall	NA
	➤ Jockey pump head	NA	Common with the mall	NA
	➤ Standby Pump out put	NA	Common with the mall	NA
	➤ Standby Pump Head	NA	Common with the mall	NA
	➤ Auto Staring/Manual stopping	NA	Common with the mall	NA
	➤ Pump House Access	NA	Common with the mall	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Common with the mall	MR
	➤ Head of the pump	40 m	Common with the mall	MR
	➤ Power supply	Required	Common with the mall	MR
	➤ Auto starting of pump	Required	Common with the mall	MR
14.	Captive water Storage for fire fighting: Common with the mall			
	• Under ground tank capacity	NA	2,00,000 litres	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10, 000 litres	30, 000 Litres Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage			
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2014/809 dated 30-06-2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer *[Signature]* 12/12

Signature of the Inspecting Officer *[Signature]* 13/12/14

Name Uday Vir Singh
Designation AD/CP

Name Mahesh Keshri
Designation DCP

~~Dy CP (W2)~~
~~CPD WCD~~
~~AD/CP~~ 18/11/18
10/11/18 FT PS

DD/W/AD/CP

Sir RP letter is put up for
sign ple.

~~CPD~~ 22/11/18
~~AD/CP~~ 19/11/18